

SQM-LL OPERATOR'S MANUAL



© Copyright 2005 - 2026
Version: 20260212

Company information

| | |
|-----------------|--|
| Mailing address | Unihedron 4 Lawrence Avenue Grimsby, Ontario L3M 2L9 Canada |
| Telephone | (905) 945-1197 |
| Website | unihedron.com |

Contents

| | |
|---|-----------|
| List of Figures | 5 |
| List of Tables | 6 |
| 1 Introduction | 9 |
| 1.1 QuickStart | 9 |
| 1.1.1 Setting up the instrument | 9 |
| 1.1.2 Other software | 9 |
| 1.1.3 FITS integration | 9 |
| 2 Measurements | 10 |
| 2.1 Getting accurate readings | 11 |
| 2.1.1 Seeing conditions | 11 |
| 2.1.2 Light pollution | 11 |
| 2.1.3 Other luminance scales | 12 |
| 3 Theory of operation | 14 |
| 3.1 Light measurement | 14 |
| 3.2 Communication to the host | 14 |
| 4 Specifications | 15 |
| 5 Hardware connections | 18 |
| 5.1 Communication to the host | 18 |
| 6 Software development | 20 |
| 6.1 Writing your own software interface | 20 |
| 6.2 Pascal | 20 |
| 7 Unihedron Device Manager | 21 |
| 7.1 Getting UDM | 21 |
| 7.2 Installation | 21 |
| 7.2.1 System requirements | 21 |
| 7.2.2 Windows | 21 |
| 7.2.3 Mac | 21 |
| 7.2.4 Linux | 21 |
| 7.3 Operation | 22 |
| 7.3.1 Start up | 22 |
| 7.3.2 Main screen | 22 |
| 7.3.3 Main menu | 23 |
| 7.3.4 File menu | 23 |
| 7.3.5 View menu | 24 |
| 7.3.6 Tools menu | 31 |
| 7.3.7 Help menu | 44 |
| 7.4 Information tab | 45 |

| | | |
|----------|--|-----------|
| 7.5 | Log Continuous | 46 |
| 7.5.1 | Import.dat into spreadsheet | 54 |
| 7.6 | Calibration tab | 55 |
| 7.7 | Report Interval tab | 56 |
| 7.7.1 | Continuous reports | 56 |
| 7.8 | Firmware tab | 57 |
| 7.9 | Configuration tab | 59 |
| 7.9.1 | Sensor arrangement | 59 |
| 7.10 | Simulation tab | 60 |
| 7.10.1 | Simulation from file | 60 |
| 7.10.2 | Test response | 61 |
| 7.11 | Accessory options | 62 |
| 7.11.1 | Humidity accessory | 62 |
| 7.11.2 | Display accessory | 62 |
| 7.11.3 | LED accessory | 62 |
| 7.11.4 | Relay accessory | 62 |
| 7.12 | Command line parameters | 63 |
| 7.12.1 | Internal startup options | 64 |
| 7.12.2 | Windows autostartup | 64 |
| 7.12.3 | Windows scheduled startup | 64 |
| 7.12.4 | Mac autostartup | 65 |
| 8 | Commands and responses | 66 |
| 8.1 | Commands | 66 |
| 8.2 | Response details | 67 |
| 8.2.1 | Reading request | 67 |
| 8.2.2 | Unaveraged reading request | 69 |
| 8.2.3 | Linear reading request | 70 |
| 8.2.4 | Inline linear reading request | 71 |
| 8.2.5 | Unit information | 71 |
| 8.3 | Calibration commands | 72 |
| 8.3.1 | Calibration information request | 72 |
| 8.3.2 | Light calibration command | 73 |
| 8.3.3 | Dark calibration command | 73 |
| 8.3.4 | Disarm calibration command | 74 |
| 8.3.5 | Manually set light calibration offset | 74 |
| 8.3.6 | Manually set light calibration temperature | 75 |
| 8.3.7 | Manually set dark calibration time period | 75 |
| 8.3.8 | Manually set dark calibration temperature | 75 |
| 8.4 | Lock settings | 77 |
| 8.4.1 | Checking lock status | 77 |
| 8.5 | Snow LED accessory | 77 |
| 8.6 | Accessories commands | 79 |
| 8.6.1 | Humidity / Temperture sensor | 79 |
| 8.6.2 | Display accessory | 80 |
| 8.6.3 | LED accessory | 81 |
| 8.6.4 | Relay accessory | 82 |
| 8.7 | Continuous reporting commands | 83 |
| 8.8 | Setting Interval reporting parameters | 85 |
| 8.8.1 | Interval reporting period setting | 85 |
| 8.8.2 | Threshold setting for interval reporting | 85 |
| 8.8.3 | Interval setting response | 86 |
| 8.9 | Simulation commands | 87 |

| | |
|---------------------------------------|-----------|
| 9 Installation | 89 |
| 9.1 Mechanical installation | 89 |
| 9.1.1 Cover selection | 89 |
| 9.1.2 Cover calibration | 89 |
| 9.1.3 Cover maintenance | 90 |
| 10 Default settings | 91 |
| 11 Firmware upgrade | 92 |
| 11.1 Details | 92 |
| 12 Calibration | 93 |
| 12.1 Recalibration | 93 |
| 12.2 Light calibration | 93 |
| 12.3 Dark calibration | 93 |
| 12.4 Confirmation | 93 |
| 13 Troubleshooting | 94 |
| 14 Glossary | 96 |
| 15 Bibliography | 97 |

List of Figures

| | |
|---|----|
| 2.1 Mpsas interpretive scale | 10 |
| 2.2 Mpsas vs NELM | 13 |
| 4.1 Front and back of standard unit | 17 |
| 4.2 Front and back of fully loaded unit | 17 |
| 5.1 SQM-LLCommunication pins | 18 |
| 5.2 SQM-LLtest setup | 19 |
| 7.1 Splash screen | 22 |
| 7.2 File menu | 23 |
| 7.3 File Open dialog | 24 |
| 7.4 View menu | 24 |
| 7.5 View : Log | 25 |
| 7.6 View:Directories | 25 |
| 7.7 Data logging header | 27 |
| 7.8 Set Location dialog | 28 |
| 7.9 Plotter window | 29 |
| 7.10 Tool : old log to dat | 31 |
| 7.11 Tool : dat to Moon csv | 31 |
| 7.12 Tool : Comm terminal | 32 |
| 7.13 Tool : .dat to .kml | 32 |
| 7.14 Tool : .dat to .kml GoogleEarth result | 33 |
| 7.15 Tool : .dat time correction | 33 |

| | |
|--|----|
| 7.16 Tool : .dat local time reconstruction | 34 |
| 7.17 RSE algorithm | 37 |
| 7.18 Filter tool data 1 | 41 |
| 7.19 Filter tool data 2 | 42 |
| 7.20 Filter tool data 3 | 43 |
| 7.21 Help menu | 44 |
| 7.22 Help : About | 44 |
| 7.23 Found device (single) | 44 |
| 7.24 Found device (multiple) | 45 |
| 7.25 USB connection details | 45 |
| 7.26 Ethernet connection details | 45 |
| 7.27 RS232 connection details | 45 |
| 7.28 Information tab | 46 |
| 7.29 Log Continuously screen | 47 |
| 7.30 Log Continuously Trigger tab | 47 |
| 7.31 Log Continuously Look tab | 47 |
| 7.32 Log Continuously Status tab | 48 |
| 7.33 Log Continuously Threshold | 48 |
| 7.34 Log Continuously alerts | 49 |
| 7.35 Log Continuously Alarm for darkness | 49 |
| 7.36 Log Continuously Transfer reading | 49 |
| 7.37 Log Continuously Transfer tab | 50 |
| 7.38 Log Continuously Annotation tab | 52 |
| 7.39 Log Continuously GPS tab | 52 |
| 7.40 Calibration tab (initial) | 55 |
| 7.41 Calibration tab (populated) | 55 |
| 7.42 Report interval tab | 56 |
| 7.43 Firmware tab | 57 |
| 7.44 Firmware selection | 57 |
| 7.45 Configuration tab | 59 |
| 7.46 Light calibration confirmation | 59 |
| 7.47 Dark calibration confirmation | 59 |
| 7.48 Sensor arrangement | 60 |
| 7.49 Fig:Simulation tab | 60 |
| 7.50 Accessories tab | 62 |
| 9.1 Housing | 89 |
| 9.2 Example cover calibration | 90 |

List of Tables

| | |
|---|----|
| 2.1 Apparent Magnitudes of Known Celestial Objects adapted from [2] | 10 |
| 5.1 J1 pin definitions | 18 |
| 7.2 Default Logs Directory Path | 26 |
| 7.3 Configfile path | 26 |

| | | |
|------|--|----|
| 7.4 | .dat to Sun-Moon-MW-Clouds values | 35 |
| 7.5 | simin.csv field description | 60 |
| 7.6 | Log continuous command line parameters | 63 |
| 7.7 | Select device command line parameters | 63 |
| 7.8 | Select features command line parameters | 63 |
| 8.1 | Summary of standard commands | 67 |
| 8.2 | rx Reading request response | 68 |
| 8.3 | r1x Reading request response | 68 |
| 8.4 | Unaveraged reading request response | 69 |
| 8.5 | Linear reading request response | 70 |
| 8.6 | Inline linear reading request response | 71 |
| 8.7 | Unit information request response | 72 |
| 8.8 | Calibration information request response | 72 |
| 8.9 | Light calibration response | 73 |
| 8.10 | Dark calibration response | 73 |
| 8.11 | Disarm calibration response | 74 |
| 8.12 | Response for manual setting of light calibration offset | 74 |
| 8.13 | Response for manually setting of light calibration temperature | 75 |
| 8.14 | Response of manually setting dark calibration time period | 75 |
| 8.15 | Response for manually setting of dark calibration temperature | 76 |
| 8.16 | Lock setting command summary | 77 |
| 8.17 | Lock setting response summary | 77 |
| 8.18 | Snow LED accessory command summary | 78 |
| 8.19 | Snow LED accessory response summary | 78 |
| 8.20 | Humidity/temperature command summary | 79 |
| 8.21 | Humidity/temperature response summary | 79 |
| 8.22 | Display accessory command summary | 80 |
| 8.23 | Display accessory response summary | 80 |
| 8.24 | LED accessory command summary | 81 |
| 8.25 | LED accessory response summary | 81 |
| 8.26 | Relay accessory command summary | 82 |
| 8.27 | Relay accessory response summary | 82 |
| 8.28 | Summary of standard commands | 83 |
| 8.29 | Continuous reporting command summary | 83 |
| 8.30 | Response of all continuous reporting requests | 83 |
| 8.31 | Interval report | 85 |
| 8.32 | Response of viewing or setting interval reporting parameters | 86 |
| 8.33 | Response of request for internal simulation values | 87 |
| 8.34 | Request simulation (S....x) | 87 |
| 8.35 | Response of setting simulation values (S....x) | 88 |
| 13.1 | Reading seem too bright | 94 |
| 13.2 | Reading is 0.00mpsas | 94 |
| 13.3 | Cannot Find UDM software | 94 |
| 13.4 | Darkroom-bag readings incorrect | 94 |
| 13.5 | UDM shuts down after starting | 95 |
| 14.1 | Glossary of terms | 96 |

List of Equations

| | | |
|-----|--------------------------------------|----|
| 2.1 | MPSAS to cd/m ² | 12 |
| 2.2 | NELM to MPSAS | 13 |
| 2.3 | MPSAS to NELM | 13 |
| 8.1 | Raw Temperature to degC | 87 |
| 8.2 | degC to Raw Temperature | 87 |

1 Introduction

Thank you for purchasing the SQM-LL. You will soon be on your way to collecting scientific data.

The SQM series of products have been used in the following applications:

- Quantitatively comparing the sky brightness at different astronomical observing sites.
- Documenting the evolution of light pollution.
- Setting planetarium dome illumination to mimic the skies that people are likely to experience elsewhere in the city.
- Monitoring sky brightness through the night, night-to-night, and year-to-year for astronomical observation records.
- Determining which nights show the greatest promise for finding the 'faintest fuzzies'.
- Calibrating the effect of sky brightness on qualitative measures such as the Bortle Scale or NELM.
- Investigating how sky brightness correlates with the solar cycle and month-to-month sunspot activity.
- Helping to provide local ground truth for future sky brightness prediction with the Clear Sky Clock.
- Helping CCD users make a correlation between the SQM reading and when the background reaches some ADC level.
- Assisting Sea Turtle researchers in studying the amounts of light in areas where turtle hatchlings are affected by artificial lights.
- Researching bird-song synchronization with dawn.
- Researching twilight brightness changes with the addition of external Neutral Density filters. Unihedron offers adapters to attach such filters onto the meter.

1.1 QuickStart

1.1.1 Setting up the instrument

1.1.2 Other software

- If you are using Windows, you may want to use Knightware SQM-Reader from www.knightware.biz/sqm .
- The CD contains examples of software (Perl, Python, etc.) for various functions that connect to the meter.

1.1.3 FITS integration

Some programs (listed below) gather information from the Unihedron Sky Quality meter products and insert that data into the Flexible Image Transport System (FITS) header.

- MaxPilote (Freeware) incorporates SQM readings from an SQM-LE/SQM-LU into the FITS header while at the same time provide constant readings in a live and updated Data Window.
- CCDAutoPilot
- FITS4Win2 uses the MPSAS keyword for sorting and filtering image files.

2 Measurements

The SQM-LL provides readings in Magnitudes per square arcsecond, abbreviated as: mpsas, and written mathematically as $\frac{\text{mag}}{\text{arcsec}^2}$.

Mpsas is a logarithmic measurement which means that large changes in sky brightness correspond to relatively small numerical changes. A difference of 5 magnitudes is a factor of 100 times the intensity. Therefore a sky brightness $5.0 \frac{\text{mag}}{\text{arcsec}^2}$ darker corresponds to a reduction in photon arrival rate of a factor of 100.

The following schematic gives a rough idea of how to interpret the readings of the SQM:



Figure 2.1: Mpsas interpretive scale

Magnitudes are an astronomical unit of measure for object brightness. Brighter objects have a lower magnitude and darker objects have a higher magnitude value. For example; a star that is 6th magnitude is brighter than a star that is 11th magnitude.

The star Vega is used as the reference point of ≈ 0 magnitude. Table 2.1 shows the apparent magnitude of some common known celestial objects.

Table 2.1: Apparent Magnitudes of Known Celestial Objects adapted from [2]

| App. Mag. | Celestial Object |
|-----------|--|
| -26.73 | Sun |
| -12.6 | full Moon |
| -4.7 | Maximum brightness of Venus |
| +0.03 | Vega, the original zero point |
| +6 | Faintest stars observable with naked eye |
| +27 | Faintest objects observable in visible light with 8m ground-based telescopes |
| +30 | Faintest objects observable in visible light with Hubble Space Telescope |

Arcsecond is the definition of an arc being divided up into seconds as follows.

1. There are 360 degrees in a circle.
2. There are 60 arcminutes in a degree, and 21600 arcminutes in a circle.
3. There are 60 arcseconds in an arcminute, and 1296000 arcseconds in a circle.

Square arcsecond (arcsec²) is the area covered by a square measuring 1arcsec \times 1arcsec .

Magnitude per square arcsecond is the definition of brightness in magnitudes spread out over one square arcsecond of the sky. For example; if the SQM provides a reading of 20.00 mpsas, that would be like saying that a light of a 20th magnitude star brightness was spread over one square arcsecond of the sky.

The "magnitudes per square arcsecond" numbers are commonly used in astronomy to measure sky brightness. More details can be found at www.stjarnhimlen.se/comp/radfaq.html

Each magnitude lower (numerically) means just over 2.5 times as much more light is coming from a given patch of sky. A change of 5 mags/sq arcsec means the sky is 100x brighter.

The darkest we've personally experienced with the SQM in a natural clear sky was 21.80.

2.1 Getting accurate readings

Various factors will cause the night sky brightness to fluctuate. Taking more readings will be useful in ruling out spurious events. The SQM gathers light for at least a one second period, and the brightness report is based on the light that was accumulated during that time.

At the darkest sites, natural variations in conditions such as airglow and the brightness of the zodiacal light are limiting factors.

Prevent artificially high (dark) readings by ensuring that there is nothing blocking the view of the sensor. Avoid taking readings near trees or buildings that may block the sensor.

A reading of greater than 22.0 is unlikely to be recorded, however there are reasons for extra dark readings:

- Cloud or ash covered sky in a remote area where little natural sky brightness can be recorded.
- Uncorrected readings from covered meter like a weatherproof housing.
- Obstructed view like inside a forest, or where large buildings are located within the field of view, or a person or bird blocking the view.

When the sky is very dark, the meter takes longer to gather enough light to produce a reading. During this time of light gathering, the reading will remain constant until the meter can start gathering readings fast enough for new reading-requests.

The readings are averaged in an 8-cell rolling buffer, so it may take a while for the meter to produce a new value of darkness when obstructions leave the field of view.

Prevent artificially low (bright) readings by ensuring that there are no lighted objects (street lamps, the moon, etc.) that shine into the sensor at any angle.

2.1.1 Seeing conditions

Scintillation is due to refractive changes in the atmosphere caused by temperature changes at differing heights.

Stars are too small in comparison to the entire SQM field of view, so scintillation is not expected to alter the SQM reading significantly.

2.1.2 Light pollution

Undesirable artificial light that reaches you is considered to be light pollution. Much of this light comes from outdoor illumination of parking lots, street lamps, office buildings, advertising signs, etc..

Other causes of extra light in the night sky are listed below:

Aurora

Charged particles emitted from the Sun are directed to the poles of the earth by the Earth's magnetic field. These particles collide with atoms in the atmosphere and cause light to be emitted. Aiming the meter at the polar regions during Aurora Borealis (in the North) or Aurora Australis (in the South) will reduce the reading (lighter). Aiming the meter towards the equator will increase the reading (darker) under these conditions.

Airglow

Airglow is light produced by various phenomenon in the atmosphere which prevent the sky from being totally dark. Effects of the magnetic poles of the Earth may cause airglow to be brighter near the poles.

The Milky Way

As one goes to sites with darker surface brightnesses, the fraction of the total light received by the SQM-LL which can be attributed to the Milky Way bulge increases and so the "offset" in mpsas will be larger (due to the Milky Way.)

The northern view of the Milky Way contributes about 0.10 mpsas under 21.5 mpsas (moonless) skies.

The southern view of the Milky Way might be as big an effect as 0.56 mpsas in dark skies where it goes near-overhead.

For more information, see Surface Photometries of the Milky Way (Schlosser+ 1997)
vizier.u-strasbg.fr/ftp/cats/VII/199/ReadMe

Moisture

Clouds, fog, and mist will reflect artificial light back down to the Earth causing a brighter (lower) reading. If there is no artificial light, then clouds may prevent starlight from coming to you and the reading will be darker (higher). This extra-dark situation can occur in very isolated areas like mountain tops, the ocean, or the desert. You will have to be aware of this special situation when analyzing readings.

Volcanic eruptions

Dust released into the atmosphere by volcanoes can reflect light from the surface of the earth back down. In a dark location this dust will prevent the light from stars and Milky Way and produce a darker (higher) reading.

Zodiacal light

The sunlight reflected off dust particles in the ecliptic plane of our solar system is called zodiacal light.

The amount of light will be different depending on whether the meter is pointed to the poles or plane of the solar system. It is likely to have less than 2% effect. The primary reason for this small effect is that the brightest and widest part of the zodiacal light is nearest the horizon where the SQM has almost no sensitivity (due to it being a primarily zenith-looking device). The portions at higher altitude are the narrowest and faintest and they would barely creep into the sensitivity cone of the SQM.

2.1.3 Other luminance scales

Candela per square meter (cd/m²) is commonly used by lighting engineers.

To convert the SQM mpsas reading to cd/m², use Equation (2.1):

$$[cd/m^2] = 10.8 \times 10^4 \times 10^{(-0.4 \times [mag/arcsec^2])} \quad (2.1)$$

Naked eye limiting magnitude (NELM)

Quite often astronomers will refer to a sky by the darkest star they can see, for example a "6th magnitude sky", in that case you can see 6th magnitude stars and nothing dimmer like 7th magnitude stars. The term "6th magnitude skies" is very subjective to a persons ability to see in the night, for example an older person might say "5th magnitude skies" but a young child with better night vision might say "7th magnitude skies".

Nobody has performed the task of defining a relationship between the two methods of sky brightness (x magnitude skies and magnitudes per square arcsecond) – probably because one is subjective and the other is objective and a wide variety of people would have to be polled.

An approximation exists for the conversion between NELM and MPSAS. You can use an NELM converter[5] created by SQM user K. Fisher to do that conversion, or the chart shown in Figure 2.2 and Equations (2.2) and (2.3).




Figure 2.2: Mpsas vs NELM

Convert NELM (V mags) to MPSAS (B) sky brightness [3]

$$B_{mpsas} = 21.58 - 5 \times \log(10^{(1.586 - NELM/5)} - 1) \quad (2.2)$$

Convert MPSAS (B) sky brightness to NELM (V mags) [4]

$$NELM = 7.93 - 5 \times \log(10^{(4.316 - (Bmpsas/5))} + 1) \quad (2.3)$$

NSU

Natural Sky Units [1] (NSU) is radiance relative to an assumed natural radiance of 21.6 magSQM/arcsec².

NSU values indicate how much brighter or darker the sky is compared to a typical historic clear night sky. It is defined here as $NSU = 10^{0.4\Delta}$ where Δ is 21.6 minus the observed value in magSQM/arcsec².

3 Theory of operation

3.1 Light measurement

The SQM-LL measures the darkness of the night sky to provide readings of magnitudes per square arc second through the Lite connection.

A light to frequency sensor (TSL237) provides the micro-controller with a signal whose frequency depends on the amount of incoming light. And, readings from the temperature sensor are used to compensate the light sensor readings through the range of operating temperatures.

In bright skies, the sensor produces a high frequency square wave (up to 500kHz). As the sky gets dark, the sensor produces a low frequency. In absolute darkness, the sensor period is very long, and is defined on the calibration sheet as "Dark period" with a 300s timeout.

Measurement of this wide range of frequencies is done by timers and counters inside the microprocessor. It is difficult for a microprocessor to accurately measure the period of high frequency signals, and just as difficult to measure the frequency of extremely low frequency signals. For this reason the microprocessor has two modes of signal measuring:

Frequency mode: The frequency mode is for bright readings where the frequency is high. The sensor signal is fed into a counter that is gated at one second intervals to report a frequency measured in Hz.

Period mode: The period mode is for dark readings where the frequency is low. The sensor signal gates a high speed internal counter which reports the period measured in μ s.

Both *Frequency* and *Period* results are available when connected directly to the meter and using the "rx" command.

The SQM-LL computes mpsas by deciding if the period or frequency report should be used and then compensating for temperature. Deciding between period or frequency mode reporting was originally done at a frequency of 354Hz, but by selecting the "Ideal crossover firmware" setting on the "Report interval" page, the switchover will be 679Hz which offers the best resolution at the switchover point.

The SQM-LL holds the updated period and frequency recordings in memory while waiting for an asynchronous user request for a reading. It is possible for the user to see stale readings if the light sensor cannot gather enough light to produce a reading before the user asks for the next report (i.e. using the "rx" command too frequently). Starting at firmware version 58, the SQM-LL can provide a status of the reading that the user has requested by using the "r1x" command which contains a status suffix character of F/P/S whose meaning is:

F: fresh FREQUENCY mode reading.

P: fresh PERIOD mode reading.

S: STALE reading indicates that this reading has not changed since the last reading because there was not enough light gathered to produce a new reading.

3.2 Communication to the host

J1 on the SQM-LL responds to serial communication commands from a connected host device.

4 Specifications

| | |
|-----------------------------|--|
| Connection | Pin header connector. 6 pins, 0.1 inch spacing |
| Physical Size | 35mm x 35mm x 15.5mm |
| Mounting holes | 29mm x 29mm for four M3 bolts |
| Lens center | Centered and 8mm from mounting screw axis (or 11mm from board end) |
| Weight | 9.65g |
| Meter precision | Each SQM-LL is factory-calibrated. The absolute precision of each meter is believed to be $\pm 10\%$ (± 0.10 mag/arcsec 2). The difference in zero-point between each calibrated meter is typically $\pm 10\%$ (± 0.10 mag/arcsec 2) |
| Field of View | The Half Width Half Maximum (HWHM) of the angular sensitivity is $\approx 10^\circ$. The Full Width Half Maximum (FWHM) is then $\approx 20^\circ$. The sensitivity to a point source $\approx 19^\circ$ off-axis is a factor of 10 lower than on-axis. A point source $\approx 20^\circ$ and $\approx 40^\circ$ off-axis would register 3.0 and 5.0 magnitudes fainter, respectively. |
| | <p>The graph shows the angular sensitivity of the SQM-L meter. The x-axis is labeled 'angle (deg)' and ranges from -80 to 80. The y-axis is labeled 'relative radiance' and ranges from 0 to 1. The data points for both horizontal and vertical planes form a very sharp, narrow peak centered at 0 degrees, reaching a relative radiance of approximately 1.0. The spread of the data points is roughly ±10 degrees, corresponding to the HWHM mentioned in the text.</p> |
| Power requirement | 7mA, 3.3V DC |
| Operating temperature range | -40°C to 85°C |
| Temperature sensor | Accuracy: $\pm 2^\circ\text{C}$ maximum at 25°C Location: Internal near light sensor, measures internal meter temperature for light sensor value compensation. |
| Temperature update rate | 4.3 seconds, 256 samples taken at 60Hz then averaged. |
| Reading response | <p>Reading response is the time from power up to first usable reading.</p> <p>Conditions:</p> <ul style="list-style-type: none"> - Ideal crossover firmware set (on UDM Report Interval tab). - BL jumper open, input high. - Tested with ``Test resp.'' button on Simulation tab while watching log. Look for ,V appended to reading result from U1x request. <p>Examples: Response-time Reading-mpsas (Light sensor frequency) 34.529s 22.60mpsas (0.10Hz signal) 11.867s 21.79mpsas (0.20Hz signal) 2.777s 20.01mpsas (1.00Hz signal) 2.082s 12.50mpsas (1.00kHz signal) 2.081s 10.0mpsas (10.0kHz signal)</p> |




Figure 4.1: Front and back of standard unit




Figure 4.2: Front and back of fully loaded unit

5 Hardware connections

5.1 Communication to the host




Figure 5.1: SQM-LL Communication pins

J1 on the SQM-LL (seen above) is used to communicate with the host. Pins definitions (shown below):

Table 5.1: J1 pin definitions

| Pin | Label | Description |
|-----|-------|--|
| 1 | 3.3V | Power supply 3.3V DC |
| 2 | BL | Bootload enable. Floats high, pull low to enable 3 second bootload window on powerup for loading firmware upgrades. When left open, the bootload window is only a few milliseconds and firmware upgrades can be done through the ICSP connector J2 with a PICKit2 device. |
| 3 | RTS | Request To Send. Not needed because the SQM-LL can keep up with commands transmitted at 115200 baud. Normally low output when requesting to send data from host to SQM-LL. High output when requesting to stop sending data from host to SQM-LL because SQM-LL is currently too busy to accept data. |
| 4 | RX | Receive. Normally low when open. Incoming data is normally high with low data pulses. The default baud rate is 115200. |
| 5 | TX | Transmit. Normally high. Outgoing data is pulsed low. The default baud rate is 115200. |
| 6 | GND | Ground |

Commands are sent from a host device through the serial port (J1-4 RX) on the SQM-LL. The SQM-LL micro-controller responds to commands by sending data strings back through J1-5 TX. Readings are gathered asynchronously by the micro-controller. Requests from the host are buffered and dealt with as time permits.

Test setup shown below:




Figure 5.2: SQM-LL test setup

6 Software development

6.1 Writing your own software interface

All of the commands and responses of the SQM-LL are documented in Section 8.

To communicate with the SQM-LL, the following general steps are required:

1. A serial 115200 baud connection must be made to the serial port assigned to the SQM-LL.
2. Data commands are sent to the SQM-LL, and it responds with a string of characters.
3. Close the serial port so that other programs can access the SQM-LL. Note: Only one connection can be made to the SQM-LL at a time. Therefore leaving a connection open constantly prevents other connections from being made.

Various examples of reading from the SQM devices are supplied on the CD and available at the Unihedron website.

Below is an example using Perl to read the SQM Lite device:

The above program prints a result like this:

```
r,-09.42m,0000005915Hz,00000000000c,0000000.000s, 027.0C
```

6.2 Pascal

The UDM program contains many examples of finding the SQM devices and reading data from them. It is open source and written in Lazarus/FreePascal. The source files for UDM are available here:

unihedron.com/projects/darksky/cd/udm/ .

7 Unihedron Device Manager

The Unihedron Device Manager (UDM) program is intended for use in maintaining and testing the Unihedron connected Sky Quality Meter products. Windows, Mac, Linux versions of UDM area available on the supplied CD. It is used to:

- Read version information.
- Request readings.
- Read and set calibration data.
- Read and set all other meter parameters.
- Install new firmware.
- Setup and retrieve data from datalogging meters.
- Continuously log data from connected meters.

7.1 Getting UDM

UDM is supplied on the CD that shipped with the SQM-LL. The latest version of UDM is available at the Unihedron website at this location

www.unihedron.com/projects/darksy/cd/

7.2 Installation

7.2.1 System requirements

The UDM is a fairly simple (but large) program which should run sufficiently on any present-day computer under the Windows, Mac, or Linux operating systems.

The Windows version of UDM can also be run in a virtualization mode using VMware Fusion. Access to the network is achieved by the menu **Virtual Machine > Network Adapter > Bridged (Autodetect)** being checked.

7.2.2 Windows

The Windows version of UDM is in a setup.exe style file located in the Windows subdirectory of the CD, for example:

`\Windows\setup1.0.0.38.exe`

Simply double-click on that file to start the installation procedure.

Note: Some antivirus software may prevent installation of UDM. Try disabling the antivirus software before installing UDM, or try right-clicking on the setup.exe file and "Run as admin".

7.2.3 Mac

The Mac OSX version of UDM is a dmg file located in the Mac subdirectory of the CD, for example:

`/Mac/udm.app.dmg`

Drag the app to the /Applications directory.

7.2.4 Linux

The Linux version of UDM is available in a Debian package separately for both 32bit and 64bit systems located in the Linux directory of the CD, for example:

`/Linux/udm_20140821-1_i386.deb`

Open the file with package installer program like GDebi.

7.3 Operation

After starting UDM, a list of found devices should appear, if your device is not listed on the screen, try clicking “Find” once more to search for connected devices.

If more than one SQM device is found, then you will have to select (click) on one of the devices, otherwise if only one device is found, then click on “Version” or “Reading” of the information tab for more information.

The tabs can be used to select various functions when working with your selected device. These tabs and their functions are described further in this document.

7.3.1 Start up

After starting the UDM program, a splash screen shown in Figure 7.1 is temporarily shown while the program searches for attached devices.




Figure 7.1: Splash screen

1. UDM searches for attached USB devices first. This step is fairly quick (a few seconds).
2. UDM then searches for attached Ethernet devices within the reach of the Ethernet network but not outside a firewall. This step may take about 30 seconds.


If no devices are found, then the main UDM program will be shown with the “found devices box” empty. You can attach an SQM device to your computer and press the “Find” button to search for the newly connected devices.

If you know that an Ethernet device is connected but it does not show up, then a network problem may be the cause. Also check the power connection to the SQM-LE.

If you know that a USB device is connected but it does not show up, then there may be a device driver issue. Check the USB device listing for your operating system. These USB devices should appear as a COMM port. Also, check the troubleshooting notes in section 13 on page 94 for possible solutions.

7.3.2 Main screen

The main screen of UDM consist of the following sections:



1. Window controls
2. Menu
3. Found devices box
4. Selected device details
5. Information section
6. Status bar

7.3.3 Main menu

The main menu of UDM consists of the items; File, View, Tools, Help as defined below.

7.3.4 File menu

The file menu is used for: opening files, finding newly attached devices, and quitting the program as shown in Figure 7.2.



Figure 7.2: File menu

File : Open

The “File : Open” menu item is used to open up previously stored log files or calibration reports.




Figure 7.3: File Open dialog

File : Find USB

The “File : Find USB” function can be used to only find attached USB devices and ignore possible Ethernet devices. The hotkey Ctrl+U can also be used instead of the mouse.

File : Find Ethernet

The “File : Find Ethernet” function can be used to only find attached Ethernet devices and ignore possible USB devices. The hotkey Ctrl+E can also be used instead of the mouse.

File : Startup options

The “File : Startup options” function can be used to set the command line startup parameters internally so that these parameters are not needed on the command line. See 7.12 for more details on the available options.

File : Quit

The “File : Quit” menu item is used to close the UDM program.

The program can also be closed from the window panel “X”.

7.3.5 View menu

The view menu allows you to enable various tabs and check other settings of the UDM program.




Figure 7.4: View menu

View : Simulation

Click on “View : Simulation” to toggle visibility of the “Simulation” tab. The Simulation tab can be used to send requests to the SQM-LL to simulate conversions of frequency and period to light meter values. See page 60 for more details.

View : Configuration

Click on “View : Configuration” to toggle visibility of the “Configuration” tab. The Configuration tab is used to configure the SQM with its calibration values when calibrated light and dark settings are being performed.

View : Log

shows a window of commands and responses sent to and received from the SQM during this session of running UDM. Some excessively repetitive commands are suppressed from this listing. The hotkey Ctrl+L can also be used instead of the mouse.

```

Started: 2012-12-03 21:21:28
Checking for USB attached devices.
Looking for Ethernet connections on this machine.
This machine uses IP: 127.0.1.1, will use a broadcast to: 255.255.255.255
Finished looking for Ethernet devices.
Sent: cx To: Received: Error: Instance not yet connected
Sent: cx To: Received: Error: Instance not yet connected
Sent: ix To: /dev/ttyUSB1 Received: i,00000004,00000006,00000023,00001752
Sent: cx To: /dev/ttyUSB1 Received: c,00000019.73m,0000170.150s,024.8C,00000008.71m,026.4C
Sent: ix To: /dev/ttyUSB1 Received: i,00000004,00000006,00000023,00001752
Sent: cx To: /dev/ttyUSB1 Received: c,00000019.73m,0000170.150s,024.8C,00000008.71m,026.4C
Sent: S,0000460800,0000000001,00244x To: /dev/ttyUSB1 Received: S,0000460800c,0000000001f,0000000244t,r,
19.74m,0000000001Hz,0000460800c,0000001.000s,028.6C
Sent: S,0000460800,0000000001,00244x To: /dev/ttyUSB1 Received: S,0000460800c,0000000001f,0000000244t,r,
19.74m,0000000001Hz,0000460800c,00000001.000s,028.6C
Sent: S,00007677999,0000000000,00244x To: /dev/ttyUSB1 Received: S,00007677999c,0000000000f,0000000244t,r,
20.30m,0000000000Hz,00007677999c,00000001.667s,028.6C
Sent: S,0001075199,0000000000,00244x To: /dev/ttyUSB1 Received: S,0001075199c,0000000000f,0000000244t,r,
20.67m,0000000000Hz,0001075199c,0000002.333s,028.6C

```

Figure 7.5: View : Log

View : Directories

shows the directory paths used by UDM to store and retrieve data.




Figure 7.6: View:Directories

Logs Directory Path shows the path where logged records are kept. These logged records are created when using the “Log one Record” or “Log Continuously” features. Also, log files from data-logging meters will be stored here from the “Retrieve All” function.

The “Logs Directory Path” path can be changed from its default by pressing the folder button the right. After the path has been changed, new log files will be stored in that new folder.

UDM operations are logged in files labelled `SNnnnn.log` and `udm.log` which are text files that are handy for troubleshooting.

Table 7.2: Default Logs Directory Path

| OS | Location |
|---------|---|
| Windows | <code>C:\ProgramData\Unihedron\logs\</code> The Windows File Explorer may hide the directory. Open File Explorer, click on the “View” tab, and check the “Hidden items” box. |
| Linux | <code>/home/user/.config/udm/</code> |
| Mac | <code>/Users/user/Documents/udm/</code> |

TZ database path The Time Zone information is required for datalogging purposes because the timestamp is logged as UTC. Since time zones change over the years, the entire Time Zone database is required and hence distributed with UDM and stored at the displayed “TZ database path”. This path is not changeable.

The Time Zone database is taken from: <https://www.iana.org/time-zones>

Firmware files path The firmware for the SQM-LL can be updated or reverted using UDM. These firmware files are stored at the displayed firmware files path. This path is not changeable.

Data Directory is the place where some data files are kept, specifically the change-log for UDM and firmware files. This path is not changeable.

Configfile path is the place where UDM stores its configuration about the program and attached SQM devices. This path is not changeable.

Table 7.3: Configfile path

| OS | Location |
|---------|--|
| Windows | <code>C:\ProgramData\Unihedron\udm.ini</code> |
| Linux | <code>/home/user/.config/udm.cfg</code> |
| Mac | <code>/Users/user/Documents/udm/udm.cfg</code> |

View : DL Header shows the Data-logger header editing page. See the information at www.darksky.org/measurements for a detailed description of each field.




Figure 7.7: Data logging header

DL : Position can be changed by pressing the Edit button which calls up the following dialog:




Figure 7.8: Set Location dialog

The “Set location” dialog is used to type in your location and have it verified on the world map. Use the following steps to set the location:

1. Type the exact location coordinates (in degrees) of the SQM-LL into the “Desired” fields.
2. The mouse pointer can be used to select an approximate location if you are not sure of the exact coordinates.
3. The “Elevation” entry is optional as it is not used for anything yet.
4. Press the “Apply” button when you are satisfied with the desired values. Note: The “Apply” button will only be enabled if there is a difference between the desired and actual values.
5. Press “Close” when you are satisfied with the actual values.

The “Local timezone region” and “Local timezone name” are required by UDM to calculate local times of the recorded data before storing to disk. UTC timestamps are stored in the SQM-LL.

The cover offset is a text only field that indicates what offset was used on the calibration data of the SQM-LL.

View : Plotter The plotter window can be used to analyze .dat files recorded by UDM. An example shown below:




Figure 7.9: Plotter window

- The left sidebar tab be expanded and contracted by clicking on the tab title bars.
- Many data points can be optionally included from the “Settings” tab.
- The plotter can also display rise/set Twilight lines for the Sun.
- The “Help” tab shows some hints for zooming and also the line color definitions of plotted lines.
- The bare plot can be saved in vector graphics (SVG) or bitmap (PNG) modes using the “Save” buttons in the “Settings tab”. Note: SVG plots require that UDM can find the fonts used on the plotter (usually Arial).

View : Plotter : Time offset To assist in correcting timing problems when the datalogger real-time-clock was not properly set, the **Time offset** feature can be used as follows if there are two datalogger files, one with proper time set, and a second with bad time setting:

- Open the Plotter
- **File mode: Multiple**
- **Settings: Display: Grid, and Darkness** only, all other display selections can be unchecked.
- Select **Plot number: 1**, then click on the reference file (with the correct timing).
- Select **Plot number: 2**, then click on the problem file.

- Enter a starting **time offset** value.
- Press **Replot**.
- Alter the offset and replot until there is overlap of the two lines at a date and time that should be overlapping.
- Record the time offset and use it in the **Tools: .dat time correction** utility as follows ...
- press "**Select file**", then select the problem .dat file.
- Enter the **time difference** which you recorded earlier.
- Press "**Correct .dat file**".

View : Plotter : Customized colors and line widths The colors and width of plot lines and can be modified in the udm.ini/cfg file (found in the View:Directories:ConfigFile path). Edit the file with a text editor and place settings under the Plotter: section, for example: MPSASColor=clRed

The following names can be used to define plot line colors: MPSASColor MPSAS2Color MPSAS3Color MoonColor SunColor CivilColor NauticalColor AstronomicalColor SunTwilightColor VoltageColor TemperatureColor

Color names or numbers are defined here: https://wiki.freepascal.org/Colors#Convert_TColor_to_2Ffrom_string

The width of a line is defined with an integer number of pixels, for example: MPSASWidth=3

The following names can be used to define plot line widths: MPSASWidth MPSAS2Width MPSAS3Width MoonWidth SunWidth CivilWidth NauticalWidth AstronomicalWidth SunTwilightWidth VoltageWidth TemperatureWidth

7.3.6 Tools menu

Tools : old log to dat

The “old log to dat” tool is used to convert the original .log files that UDM created before the .dat file was made standard. Figure 7.10 shows the setup dialog for conversion.




Figure 7.10: Tool : old log to dat

Tools : dat to Moon csv

The “dat to Moon csv” tool is used to convert .dat files to a csv file that contains Moon data using algorithm library from Andreas Hörstemeier [6]. This tool prepares the file for importation into a spreadsheet like Excel, OpenOffice, or LibreOffice. For importing into a spreadsheet.

The value for “Moon phase angle” reported in the .csv is:

- 180 or -180 = New Moon
- 0 = Full Moon
- Positive numbers Waxing (growing)
- Negative numbers Waning (shrinking)




Figure 7.11: Tool : dat to Moon csv

Press the “Select ...” button shown in Figure 7.11 to select the file and start the conversion process.

You may also be interested in the “Excel import” instructions listed in section 7.5.1.

Tools : Comm terminal

The “Comm terminal” is a communication terminal window used for sending manual commands and viewing the response of the selected (from the found devices window) device.




Figure 7.12: Tool : Comm terminal

Tools : DL retrieve

The “DL retrieve” tool is used for datalogging and Vector model to pull in data files that were stored on disk previously.

Tools : .dat to .kml

Creates a .kml file from a .dat file. This is used when the SQM-LL and an external GPS are read by UDM in the Log Continuous datalogging mode.




Figure 7.13: Tool : .dat to .kml

The .kml file can be imported into GoogleEarth to create an image similar to this:



Figure 7.14: Tool : .dat to .kml GoogleEarth result

This tool uses a legend image (kmllegendnewatlas.png.png or kmllegendcleardarksky.png) which must be available to GoogleEarth to properly display the legend. The resultant .kml file and legend file is stored in the “Logs directory path”.

A minimum set of data can be used by UDM to produce a map with only the MSAS brightness, Latitude,Longitude. The timestamp

The data file (with .dat extension) requires a definition line which contains at least the following fields:

```
# UTC Date & Time,MSAS,Latitude,Longitude
```

A minimum example of a data file showing three data records:

Listing 7.1: .dat minimum field example

```
# UTC Date & Time,MSAS,Latitude,Longitude
2018-02-07T04:27:57.642;19.0;33.2208;-116.3387
2018-02-07T04:28:17.089;18.3;33.2208;-116.3422
2018-02-07T04:28:37.105;18.0;33.2210;-116.3457
```

The UTC Datestamp data is not used to make the .kml file, but UDM requires something there.

The format of the fields are:

```
# YYYY-MM-DDTHH:mm:ss.fff;mag/sqarcsec;Degrees;Degrees
```

Tools : .dat time correction

Corrects a .dat file for out of synch timing by a manually entered offset. See figure 7.15.

This may be useful when the battery has expired in the datalogging meter, or if the clock was not set at the beginning of the datalogging session.



Figure 7.15: Tool : .dat time correction

Select the .dat file for correction.

Enter the manual time offset correction (in seconds).

Press the “Correct .dat file” button to write the corrected file to disk. The location of the new file is shown in the bottom Filename section.

Tools : .dat reconstruct local time

This tool is used when the datalogger timezone was not set properly. The local timestamp is recomputed for each record based on the timezone selections. One .dat file or a directory of .dat files can be corrected.




Figure 7.16: Tool : .dat local time reconstruction

Select the desired .dat file or directory of files to reconstruct.

The "Standard" timezone usage uses a selected timezone region and timezone as the basis for computing the local time stamp from the existing UTC timestamp.

The "Custom" timezone usage allows the user to enter a custom time offset in hours as the basis for computing the local time stamp from the existing UTC timestamp.

Press the "Reconstruct .dat local times" button to start the process.

If a single input file was selected, then the corrected output file will be stored in the same directory with "_LocalCorr" appended to the filename.

If a directory of input files was selected, then the corrected files will be stored in a subdirectory called LocadCorr, and each file will have "_LocalCorr" appended to its filename.

The reconstructed file(s) will be written to disk at the location specified in the bottom Filename section.

Tools : .dat time correction

If the real-time-clock inside the datalogger was not set properly or the battery was not plugged into the datalogger quickly enough to keep the super-capacitor charged before datalogging began, then there would be a difference in time when the data was retrieved. The .dat file can be corrected with this tool.

Tools : .dat to Sun-Moon-MW-Clouds .csv

Reads a .dat file of SQM data and creates a comma separated value (.csv) file with these attributes at each SQM time reading.

Table 7.4: .dat to Sun-Moon-MW-Clouds values

| Label | Description |
|------------------|--|
| Location | Geographic name of SQM site, taken from "Location name" in raw data file; if blank the Location is printed as "Not-Specified" |
| Lat | Latitude of SQM, in fractional degrees, taken from Position value in raw data file; if blank, processing will stop |
| Long | Longitude of SQM, in fractional degrees, taken from Position value in raw data file; if blank, processing will stop |
| UTC_Date | Universal date extracted from raw data file "UTC Date & Time" |
| UTC_Time | Universal time extracted from raw data file "UTC Date & Time" |
| Local_Date | Local date extracted from raw data file "Local Date & Time" |
| Local_Time | Local time extracted from raw data file "Local Date & Time" |
| Celsius | Temperature of SQM, degrees Celsius, extracted from raw data file "Temperature" |
| Volts | Voltage of SQM, volts (battery supply), extracted from raw data file "Voltage" |
| Msas | SQM reading (Magnitudes per arc second squared) |
| Status | SQM record type |
| MoonPhase | Phase of the moon in degrees, 0 degrees = Full Moon; + and -180 degrees = New Moon; waxing Moon from +180 to 0 degrees: waning Moon from 0 to -180 degrees; values flip from -180 to +180 at Full Moon |
| MoonElev | Elevation angle in degrees of the moon above or below (negative) the local flat horizon |
| MoonIllum | Percentage of moon illuminated |
| SunElev | Elevation angle of the sun above or below (negative) the local flat horizon |
| MinSince3pm | Number of minutes since 3pm of the previous day; allows tracking of time from afternoon, through evening, night and morning; positive number |
| Msas_Avg | Average value of SQM reading during the current night, under conditions of sun lower than 18 degrees below the horizon and moon lower than 10 degrees below the horizon |
| NightsSince_1118 | Number of nights since January 1, 2018; useful to track number of nights since that day |
| RightAscensionHr | Right ascension in hours of the zenith at the SQM location; equivalent to Local Siderial Time at the SQM location; used to calculate the Galactic orientation |
| Galactic_Lat | Angle in degrees between the zenith at the SQM location and the highest point of the Milky Way Arc; value of zero implies the SQM is pointed directly into the Milky Way |
| Galactic_Long | Angle in degrees from the Galactic Center (Sagittarius) eastward along the Galactic equator |
| J2000days | Days since January 1, 2000; fractional |

Table continued on next page ...

Table 7.4 – *continued from previous page*

| Label | Description |
|-------------|--|
| ResidStdErr | Residual Standard Error multiplied x1000; a measure of jaggedness of the SQM data over a time range specified by the user (typically 90 minutes); if RSE is large, for example > 50, then conditions can be considered to have been cloudy |

ResidStdErr – some details:

Scattered clouds passing overhead cause variations in the SQM brightness readings - a plot over time under a cloudy sky tends to be very jagged. See Figures 2 and 3 of this report https://5023ce21-5614-48fc-a5d4-292b92640d50.filesusr.com/ugd/445aec_7522a23976bc472f8dbdcfb907d5d5b7.pdf by Bill Kowalik, and Michael McKeag, Oregon Chapter of International Dark-Sky Association.

ResidStdErr is a measure of the jaggedness or roughness of the SQM data over time. Large values indicate cloudy conditions. Small values represent clear conditions. You can later filter out cloudy data by only accepting data points characterized by a small RSE value.

This cloud estimation algorithm fits a linear regression to the SQM data over a time range, and calculates the Residual Standard Error (RSE), a measure of the fit between the linear regression and the actual SQM data. See Figure 7.17.




Figure 7.17: RSE algorithm

We have been using a 90-minute time span as shown in the Figure 7.17. The RSE value is assigned to the point in the middle of the time span. The time window advances one time step (typically 5 minutes in our data files) and the fit is calculated for the new center point, etc.

This algorithm processes one day of data at a time. Assuming a 5-minute sample spacing in time, there are at most 288 samples per day, so arrays are dimensioned to 300; attempts to process SQM data with time spacing that provides more than 300 samples per day will fail.

The Range parameter is the number of samples (usually 5 minutes apart) to include before and after the current point at which the Residual Standard Error of regression calculation is performed; the full width of the interval in terms of number of points to consider in the calculation is $(2 \times \text{Range} + 1)$ so that a Range of 6 incorporates a time span of 60 minutes and a Range of 9 evaluates to a 90 minute span.

Additional Notes:

1. If the Latitude and Longitude are not specified in the input .dat file, processing will stop.
2. If the Location name is not specified in the input .dat file, the location name will be printed in the output .csv file as "Not-Specified".

3. A night sequence is considered to begin at 1500 Local Time.
4. The first Range number of points in a day and the final Range number of points in a day are assigned dummy RSE values of 999000.0
5. During daylight hours when the entire Range of values has SQM readings of 0.0, the RSE values is reported as 0.0

Tools : Filter Sun-Moon-MW-Clouds.csv

Reads a csv file created previously by the “UDM/Tools/.dat to sun-moon-MW-clouds.csv” program and allows you to: a) Filter that csv file for select data records and b) Apply data adjustments. For example, you can set filter parameters to find data records that were recorded during cloud-free nights. You can apply an adjustment for data recorded because the SQM was inside a weatherproof case. Data records selected by the filters are written out to two separate csv files, with keyword labels “Dense” and “Sparse”, as described below.

Parameters:

1. Sun elevation angle cutoff in degrees - includes records with sun elevation angle less than or equal to this value (default -18.)
2. Moon elevation angle cutoff in degrees - includes records with moon elevation angle less than or equal to this value (default -10.)
3. Cloud algorithm cutoff - includes records with residual standard error (cloud parameter) less than or equal to this value (default 20.)
4. Galactic Latitude elevation angle in degrees - cutoff to eliminate Milky Way from FOV, includes records with galactic latitude greater than this value (symmetric, positive and negative) (default 0.)
5. Correction for weatherproof cover – value subtracted from SQM readings to account for darkening caused by presence of weatherproof cover (default 0.11)
6. Correction for aging of the SQM - estimate of the increase of brightness reading (darkening) per year due to sunlight exposure (default 0.01897)
7. Max MPSAS allowed - includes records with MPSAS values less than or equal to this value (default 22.0)
8. Sparse cutoff – after the above filters are applied, segregates data records remaining, which are estimated to be caused by constant cloud cover, fog, smoke into the “Sparse” output file; the majority of remaining records are written to “Dense” output file; specify a larger value to segregate more data records; set to zero for no segregation in which case all remaining records go into the “Dense” output file (default 25)

Explanation of Parameters:

1. Sun elevation – a generally accepted convention is that the sun must be at least 18 degrees below the horizon to mark the beginning of astronomical darkness
2. Moon elevation – a generally accepted convention is that the moon must be at least 10 degrees below the horizon to not compromise sky brightness measurements
3. Cloud cutoff – filters on the residual standard error (RSE) attribute previously calculated by the “UDM/Tools/.dat to-sun-moon-mw-clouds.csv” program. This parameter allows the user to select skyglow measurements taken during clear, cloud-free, nights. The previously calculated RSE attribute measures the “jagginess” of the skyglow data over a relatively long time period, for example 90 minutes. If the skyglow data are relatively smooth over that time period, the sky is assumed to be clear, and the center point of that time range is considered to be a clear sky measurement. A cloud cutoff of 20 is recommended. To include more data points, use a larger cloud cutoff value.
4. Galactic Latitude – as calculated in “UDM/Tools/.dat to sun-moon-mw-clouds.csv”, the galactic latitude is defined as the angle between the zenith at the SQM location and the highest point on the galactic plane. This parameter allows the user to eliminate any records recorded when the SQM was pointing into the Milky Way. When tabulating data for certification of dark sky places, we want to eliminate any data recorded when the Milky Way was in the field of view of the SQM; that FOV is nominally 20 degrees; we suggest a 30-degree cutoff as a conservative approach. This one value is applied symmetrically on the positive and negative side of the zenith. Choose parameter value of zero to prevent exclusion of data records on the basis of the galactic latitude.

5. Correction for weatherproof cover – the presence of the weatherproof cover causes the SQM to read darker values, which yields a higher mags/arc second squared value; this correction value is subtracted from the SQM reading to account for the weatherproof cover.
6. Correction for aging of the SQM – Recent research documents that as the SQM devices age over multiple years with exposure to the sun, that there is a darkening effect on measured data – in other words, the meters read slightly darker values than they should. This parameter applies a correction to the data based on the progressive age of the SQM. The correction is absent at the beginning and increases with duration of exposure. The algorithm assumes that the first data in the SQM file was recorded when the SQM was new and that the SQM was continuously mounted outdoors to the end of the data records. The default estimate is 0.0189 magnitudes per arc second squared per year of exposure time.
7. Max MPSAS allowed – after the adjustments described above, data records higher than Max MPSAS allowed will be deleted. Cloudy night skies in areas lacking light pollution will record high values, such as 23.5 or 24.0 magnitudes per arc second squared because the clouds appear black and block the stars from view. And, these dark clouds may not be eliminated by either the cloud algorithm or the sparse algorithm (described next). It is widely believed that most clear and skyglow-free night skies will not exceed 22.0 magnitudes per arc second squared, which is the default parameter value. However, graphical inspection of your data may show that pristine night skies will show valid values of about 22.10 magnitudes per arc second squared. This cutoff ensures that unexpectedly large values are excluded from clear sky summary data.
8. Sparse cutoff – At times, the SQM will record data under night sky conditions such as constant cloud cover, fog, smoke or snow. It is desirable to eliminate these data records to avoid contamination of estimates of clear night sky summary statistics.

Because the SQM may record relatively constant values under these conditions, those SQM records will not be filtered out by the cloud algorithm, which assumes variability of data to detect cloudy conditions. The sparse cutoff parameter governs an algorithm designed to detect and segregate those relatively constant, non-clear sky data records. Choose a sparse parameter value of zero to prevent any data points going to the sparse bucket. An alternative to this automated approach is to manually delete the non-clear sky data points in some other graphical software.

After any sun, moon, Milky Way and cloud parameters are applied to filter the data, and after any data adjustments are applied, this algorithm creates an internal 2D plot of time-of-night versus SQM readings. Most of the data will overplot itself in a “dense” pattern, which is characteristic of the most commonly occurring clear sky conditions at that SQM site. SQM data recorded under nearly constant, non-clear skies (overcast, foggy etc) will occupy less dense areas of the 2D plot, either above or below the area of dense data on the plot. The goal of this algorithm is to remove those “sparse” data points by spatial filtering in that 2D plot. Figures 7.18 and 7.19 show the impact of this sparseness filter process.

The sparseness algorithm sets up an internal 2D plot in X and in Y. The X dimension is MinutesSince3pmStdTime, and ranges from 0 to 1440 minutes, divided into 5-minute-wide bins. The Y dimension is MPSAS (magnitudes/arc sec squared) and ranges from 0 to 23, divided into 0.05 mags/arc second sq tall bins.

This algorithm passes a 2D filter over the data in the 2D plot (Figure 7.20). At each occupied cell of the 2D plot, it sums the population count in 12 nearby cells, around the central target cell. If the count is small, and less than the sparseness parameter (for example, 25), it is considered to be a sparse point, and target cell data record is written out to the “Sparse” csv file. If not, the target cell data record is written out to the “Dense” csv file.

As shown in Figure 7.20, the 12 nearby cells are seven cells tall with a central 3x3 area, excluding the target cell. The blank point in the middle of the filter is the target point. The area processed is taller than is wide because the sparse points tend to have blank areas above them in the XY scattergram. The tall pattern is designed to successfully identify the sparse points.

This program creates three output files:

1. A csv file of the selected data records labelled “Dense” this file contains those data records which pass the sun, moon, cloud, Milky Way, max MPSAS allowed and sparse cutoff filters - i.e. “dense” data which represents the most commonly occurring data at an SQM site; this file has the same format at the input .csv file

2. A csv file of the selected data records labelled “Sparse” which pass the sun, moon, cloud, milky way and max MPSAS allowed, but which are segregated by the sparse cutoff test - these are the scattered data points which passed the cloud removal filter, but which are probably caused by constant cloud cover, fog, snowy conditions, etc.; this file also has the same format at the input csv file
3. A text file that lists the parameter values and summary statistics for the filtered data. After the filtering for sun, moon, MW and clouds, and applying any corrections specified, the text file lists the mean, min and max of the selected data points. This is a summary of the combined records of the “Dense” and “Sparse” output files.

And, after filtering out any sparse points, the text file lists the mean, min and max again. This is a summary of the records in the “Dense” output file. If parameters are chosen well, this is a summary estimate of the brightness of the night clear sky data recorded by the SQM.

For quality control, it is good practice to graphically display both the “Dense” and the “Sparse” csv files. Graphical display allows you to understand the implications of your parameter choices. For example, you may want to change the cloud cutoff value to exclude more records or the sparse cutoff value because too many, or too few, of the data points were assigned to the sparse bucket.

Dense & Sparse Data after sun, moon, milky way, clouds filtering, from one SQM site




Figure 7.18: Several years of data from one SQM site summarized in a 2D plot, after filtering for sun, moon, Milky Way and clouds. Colors are proportional to the number of data points at each cell of the plot. Red represents most frequent points, blue least frequent. The goal of the sparseness filter is to remove the data points that plot away from the most dense data, to avoid bias of measurement of the clear night sky brightness. See Figure 7.19


Dense Data after sun, moon, milky way, clouds, sparseness filtering, from one SQM site

Figure 7.19: Same data as Figure 7.18, but after application of the sparseness filter. The remaining data can provide a good estimate of the night sky brightness at this SQM location.




Figure 7.20: Diagram of the sparseness filter. Blue squares represent SQM measurements acquired under infrequent overcast or foggy conditions. The goal of the sparseness algorithm is to identify them for segregation into the “Sparse” output csv file.

7.3.7 Help menu




Figure 7.21: Help menu

Help : Online manuals shows online links to the meter manuals. Click on the desired meter to open that PDF manual in your browser.

Help : Online resource links to the updated online Unihedron resource files that are sent out with each meter.

Help : Cmdline Info shows the commands that can be used when starting UDM from the command line.

Help : Version Info shows the detailed version information for the UDM software.

Help : About displays a simple screen with the version identifier.



Figure 7.22: Help : About

Found devices box shows all the connected SQMs available that UDM can find from this computer.

If only one device is found, then UDM auto-selects it and gathers the version information for that selected device.




Figure 7.23: Found device (single)

If more than one device is found, then UDM does not select any of the devices. You may select the desired device by clicking in the found devices box on the SQM that you want to know more about. Once you select the device, then the

connection details are displayed. Clicking on the “Version” or “Reading” button will gather more information from the meter.



Figure 7.24: Found device (multiple)

Device details shows the connection details of the selected SQM listed in the “Found devices” box.

The USB “Port” field is editable so you may enter your own port that might not be defined in the found box. See Figure 7.25.



Figure 7.25: USB connection details

The Ethernet IP and port fields are editable so you may enter your own IP and port that might not be defined in the found box. The default port number for the SQM-LE is 10001. See Figure 7.26.



Figure 7.26: Ethernet connection details

The RS232 fields are editable so you may enter your own port and baud rate. The baud rate for the SQM-LR is 115200. See Figure 7.27.



Figure 7.27: RS232 connection details

7.4 Information tab

The information tab is used to show information about the version and the reading of the selected SQM.

Press the “Version” button for an updated list of data about the device version, and press the “Reading button” for an updated list of data about the device reading.




Figure 7.28: Information tab

The Header button calls up the data file header entry screen, see the datalogging Header section on page 27 for more information. This header information is used when storing logged data to the disk with the “Log one record” or “Log continuous” functions described below.

Log one record gathers one data record from the connected SQM and stores that information to a data log file on the disk in the “Logs directory path”. The location of the file can be identified and changed by “View : Directories”. The log file can be accessed later from the “File : Open” menu.

7.5 Log Continuous

The “Log continuous” function allows data from the connected SQM device to be logged repetitively as shown in Figure 7.29.



Figure 7.29: Log Continuously screen

Log Continuous Trigger options must be defined before logging, see Figure 7.30 for possibilities:




Figure 7.30: Log Continuously Trigger tab




Figure 7.31: Log Continuously Look tab




Figure 7.32: Log Continuously Status tab

To operate the continuous logging function:

1. Select the frequency of logging from the trigger tab.
2. Select if “Moon data” is to be computed and logged.
3. Select “Freshness” to identify Fresh/Stale results. This is useful when recording brightness from a moving platform, specifically.
4. Enter “Split (local time)” to adjust the starting time of the recorded .dat file. The default is at 0 (midnight), but you can set that to 12 to have the night time readings centered in the .dat file and plot views.
5. Select “Single .dat file” to prevent separate daily files being created each 24 hours.
6. Select “GoTo accessory” when the meter is mounted on a GoTo tripod and direction commands come from the GoTo tab.
7. Select “Raw frequency” when the rFx command is desired which send the linear raw light reading frequency. (Firmware 75 and above).
8. Select a limit to the number of records. A value of zero is default and means there is no limit. Any other value 1-1000 means that UDM will stop recording after that many records have been taken.
9. Press the “Record” button. The records are stored in a logfile whose location is shown in the “Logfile name” area. A new logfile is automatically created at the beginning of each day (at local time 0:00).
10. Press the “Stop” button when you want to stop the recording process.
11. Log files can be accessed by the “File : Open” menu selection or by pressing the “folder” button shown in the “Log Continuously” screen.
12. Press “Close” when done with the continuous logging feature.

Threshold to record A threshold for recording readings can be set before starting recording. Any reading greater or equal to this threshold value will be recorded in the log file.




Figure 7.33: Log Continuously Threshold

A threshold of 0 will allow all readings to be recorded.

The threshold indicator will turn green if the threshold of the triggered reading is met (recording) and red if the triggered reading is below the threshold (no recording).

The threshold value is saved in the registry configuration file when it is changed. Changes can only be made while not recording.

An override from the command line options (-LCTH,x) can be made. The override will only take effect for the current session and will not alter the saved configuration.

Audio alerts In cases where you want to be alerted that a reading will be taken, for example, when manually pointing the meter, the Pre-reading audio alert named **prereading.wav** can be enabled as shown in (Fig. 7.34) to play an audio file two seconds before the light meter record is logged. The “Test” button plays this file for test purposes.

Also, an optional reading alert sound file named **freshreading.wav** can also be played exactly when the reading has been gathered by selecting an option from the reading alert box. By selecting “Fresh only”, the sound is only played when the meter gathers a “Fresh” reading (Fresh readings are defined in the Light measurement section 3.1). By selecting “All”, the sound is played after every light meter reading has been recorded.




Figure 7.34: Log Continuously alerts

The audio files are located in the Data Directory (which can be identified from the main page **View→Directories**).

Alarm for darkness When the darkness is over the threshold amount, an audio file can be enabled to play (Fig. 7.35) . The Test button plays this file for test purposes. The audio file is named **alarmsound.wav** and is located in the the Data Directory (which can be identified from the main page **View→Directories**).




Figure 7.35: Log Continuously Alarm for darkness

Transfer reading Each reading can be sent by TCP to an external destination (remote) server.




Figure 7.36: Log Continuously Transfer reading

To set up this feature:

1. Enter the IP address of the destination server.
2. Enter the port of the destination server.
3. Check the Enable box.
4. Start logging.

The TEST button is available to check if the reading packet can be sent to the destination server.

To send data to the Globe at Night server:

- Make an email request to globeatnight.network@gmail.com
- Provide your GPS location.
- Provide your City/State/Country.
- Provide your serial number.
- Ask them for the IP address and Port number.
- Double check with them at a later date that your readings have been received.

An example packet which contains the reading and the serial number (Rx reading response) looks like this:
r, 00.00m,0000547954Hz,0000000000c,0000000.000s, 022.8C,00000494

Transfer file The .dat file can be sent via FTP, SCP, or SFTP to a server by making settings on the left side of the Transfer tab (shown in Fig. 7.37)




Figure 7.37: Log Continuously Transfer tab

The following transfer protocols are available:

- **FTP** (File transfer protocol).
- **SCP** (Secure file Copy) transfers require that the `scp` command exists externally from UDM. For Linux and Mac, the `scp` command is `scp` and can be proven to exist with the `which scp` command. In Windows, if you do not have access to `scp`, you may have to install a program called `pscp` and rename it to `scp`. Make sure that the SSH connection from the UDM machine to the remote machine can be opened without a password. You will have to copy the public key etc. to make a passwordless connection.
- **SFTP** (Secure File Transfer Protocol) assumes that the `sftp` command exists. This is not available for Windows at this time.

Files will be sent to the server using one or more of the following options:

- **.dat** sends the date-named .dat file which contains recorded readings.
- **.csv** sends the date-named .csv file which contains recorded readings in comma separated variable format.
- **Plot** sends the daily plot and an html file that can be used to display on a web server (details below)

Timeout (ms): tells UDM how long to wait before giving up on the transfer. When all is working well, a value of 1000ms (one second) should be sufficient.

The **Results** box shows some testing diagnostics.

The **Local filename**: is the path and file name that will be transferred to the remote server.

The **Remote filename**: shows the path and name of the file that should be sent to the remote server.

The **Test** button will initiate a transfer for testing the settings were results are shown on the screen beside and below the **Test** button.

When the **Plot** option is selected, UDM fills in the sqm-template.html file in the data directory with reading and date variables, then sends the resulting filled-in information as sqm.html to the server. A date-named plot file is also sent (its name is defined as startdate.png and encoded inside sqm.html in the imagename variable described below).

The possible variables that you can use in the sqm-template.html are:

- `<!-- SQM-location -->` The location name taken from the associated header entry.
- `<!-- SQM-coordinates -->` The GPS coordinates taken from the associated header entry.
- `<!-- SQM-timestamp -->` The timestamp of the current reading.
- `<!-- SQM-nexttimestamp -->` The timestamp of the next reading.
- `<!-- SQM-mpsas -->` The current reading in mpsas.
- `<!-- SQM-ne1m -->` The current reading in mpsas.
- `<!-- SQM-cdm2 -->` The current reading in mpsas.
- `<!-- SQM-mcdm2 -->` The current reading in mpsas.
- `<!-- SQM-NSU -->` The current reading in Natural Sky Units.
- `<!-- SQM-Best -->` The best reading of the plot in mpsas.
- `<!-- SQM-BestTime -->` The time that the best reading was recorded.
- `<!-- SQM-imagename -->` The filename of the plot file, will be something like 20220501.png.

Each variable must be on its own separate line in the sqm-template.html file, and the variable must start at the beginning of the line. See the sqm-skeleton.html file for an example. If the sqm-template.html does not exist after initial installation, then it is created from a copy of sqm-skeleton.html file located in the initial program installation directory

Annotation settings While the “Log Continuous” mode is recording data, annotations can be made to the log file records with hotkeys. The Annotation tab allows the definition of hotkeys and their associated annotation text that will appear at the end of an annotated record.




Figure 7.38: Log Continuously Annotation tab

Persistent annotation The “Persistent” mode makes the annotated text persistently appear at the end of each logged record after the first time the hotkey is pressed.

Without “Persistent” checked, annotation text is only appended to a record when the hotkey is pressed, and other records have no annotation text.

Synchronized annotation The “Synchronized” mode postpones annotation requests until the next scheduled record so that the annotated text is synchronized with scheduled triggered recordings.

Without “Synchronized” checked, the hotkey will immediately trigger a record log, and the associated annotation text will be appended to that triggered record.

GPS UDM will read the data produced from an externally connected USB or serial GPS receiver like the GlobalSat BU-353 GPS. Also the Bluetooth GPS Dual XGPS160 has been test on a Mac.




Figure 7.39: Log Continuously GPS tab

The following GPS units have been tested with the latest UDM software:

| GPS | Connection | Settings |
|---------------------------|------------|-----------------------|
| GlobalSat BU-353 | USB | 4800 baud |
| GlobalSat BU-353 S4 (5Hz) | USB | 115200 baud |
| Dual XGPS160 | Bluetooth | See GPS owners manual |

Enter the communications port name (see below) into the Port field, the baud rate into the baud field, then enable the GPS. Once enabled, UDM continuously scans the GPS port for three NMEA words.

GPS on Windows 10 To get the Communications Port for a USB connected GPS to a Windows 10 computer:

1. Click Start → Settings → Devices → Connected-devices
2. The GPS should show up there as "Prolific USB-to-Serial Comm Port (COMx)". note which Comm port is listed, one example is COM6 GlobalSat BU-353 S4 (5Hz)
3. Make sure that no other programs are accessing the GPS.
4. Start up UDM, make sure you meter is selected
5. Select Log Continuous → GPS-tab
6. Enter the Comm Port into the Port: field, in my case I just typed in COM6
7. Enter the baud rate for the GPS into the Baud: field, in my case I just typed in 115200

GPS on Mac To get the Communications Port for a USB connected GPS to a Mac computer:

1. Follow the instructions for driver installation on the CD provided with the GPS
2. Connect the GPS
3. Open a terminal window
4. Type in: `ls -altr /dev/*` to look for the most recently created file that looks something like `cu.usbserial`
5. The newly connected GPS is located at something like `/dev/cu.usbserial`
6. Make sure that no other programs are accessing the GPS.
7. In UDM → Log-continuous → GPS → Port:, type in that filename. An example would be: `/dev/cu.usbserial`
8. Enter the baud rate for the GPS into the Baud: field, in my case I just typed in 115200

GPS and SQM startup procedure Some computers reassign the communications port at power up or re-connection, so to ensure that the UDM can recognize both the SQM and the GPS, please follow these steps:

1. Disconnect the SQM and GPS from computer before powering up.
2. Power up the computer.
3. Start up UDM.
4. Connect the SQM and ensure you get a reading.
5. Disable the GPS connectivity from the log continuous tab.
6. Connect the GPS, and under the Log Continuous GPS tab ensure you are getting GPS location data.
7. Carry on from there.

GPS status Upon successful parsing of the GPS data, UDM illuminates (with bright green) the associated indicators (GPRMC, GPGGA, GPGSV). If too much time passes, the indicators fade to black.

The signal strength group shows the signal to noise ratio (SNR) for all visible satellites. The satellite number is displayed below each signal strength meter.

The location, speed, time, and status information is displayed as it is received.

If the GPS is enabled before logging, then the logfile is forced to "MOVING" platform mode, and five fields (latitude, longitude, elevation, speed, number of satellites in view) are appended to each record.

GoTo A GoTo pointing device accessory can be controlled by UDM for the purpose of pointing the meter to various parts of the sky and automatically gathering a reading at each position.

The following GoTo devices are currently supported:

- SynScan V4
- iOptron 8408

The connection of the GoTo device is made to the serial port. Note; some USB to RS232 serial adapters do not act properly with UDM. Usually an FTDI adapter should work well.

Select the machine type, port, and baud rate. Ensure that the connected device is actually available on the port you select. In Windows, you can use the Device manager, In Mac and Linux, you can type **dmesg** on the command line in a terminal window to see the latest USB device attached.

A script file containing the positions is located in the “Data Directory” which is identified by:
View→Directories→Data_Directory.

On a Mac, you can use Finder to go to “Applications”, then right click on “udm” or “udm.app” then select “Show contents”. Then you can navigate to Contents→Resources to see the location of the *.goto file(s).

The format of the GoTo script file is a semicolon-separated file with an extension of “.goto”. Comment lines are preceded by the pound symbol (#). The second line defines the field format (Zenith;Azimuth). The remaining lines define the points to move to. An example is:

```
# Default
# Zenith;Azimuth
0;0
15;0
15;60
15;120
```

Control of the positioning is done from the trigger page. The “Goto accessory” and “Freshness” check boxes must be set. Pressing the “Record” button will start the pointing sequence.

7.5.1 Import.dat into spreadsheet

The .dat file generated by UDM can be imported into a Microsoft Excel spreadsheet for calculations and graphing purposes as follows:

1. Start excel
2. File Open
3. Select “All files”
4. Select your .dat file (previously recorded and saved).
5. Select “delimited” (as opposed to the default “fixed width”)
6. Import starting at line 33
7. Next
8. Unselect “Tab”
9. Select “Semicolon”, you should see bars separating the data fields now.
10. Next
11. Define each field. European users will have to select “Advanced”, then change the “Decimal point” to “.” and “Thousands separator” to “,”
12. field 1,2 = date YMD

Note: You can also use the “.dat to Moon .csv” tool shown in Fig. 7.11 to create a comma separated variable file for importing into a spreadsheet like Excel.

7.6 Calibration tab

The Calibration tab is used to show and set the calibration data for the selected SQM device.

| Desired Values | Actual Values |
|--------------------------------|---------------------|
| Light Calibration Offset: | Set 0.00 mpsas |
| Light Calibration Temperature: | Set 0.00 °C |
| Dark Calibration Period: | Set 0.00 s |
| Dark Calibration Temperature: | Set 0.00 °C |

Notes:

- See calibration sheet for original settings.
- Add/subtract Light Cal offset for extra glass covering.
- Temperature values get reconverted, so the actual may be slightly different than the desired.

Figure 7.40: Calibration tab (initial)

Press the “Get Calibration Info” button so that the updated calibration data is brought in from the SQM on to the Actual values boxes as show below.

| Desired Values | Actual Values |
|--------------------------------|----------------------|
| Light Calibration Offset: | Set 19.73 mpsas |
| Light Calibration Temperature: | Set 24.8 °C |
| Dark Calibration Period: | Set 170.150 s |
| Dark Calibration Temperature: | Set 26.4 °C |

Notes:

- See calibration sheet for original settings.
- Add/subtract Light Cal offset for extra glass covering.
- Temperature values get reconverted, so the actual may be slightly different than the desired.

Figure 7.41: Calibration tab (populated)

Use the following steps to change the calibration values:

1. Enter the new calibration data on the left side entry box (Desired values column).
2. Press the associated “Set” button.
3. The value is sent to the SQM, and then confirmed in the right side box (Actual values column).

Note that temperatures set in to the SQM use their own resolution and may not be reflected as the same value entered. For example. 24.7°C might read back as 24.8 °C.

The original factory calibration values were provided on a paper with the shipped unit. If you have lost this information, please contact Unihedron to have the information emailed.

7.7 Report Interval tab

The Report Interval tab is used to show and set the report interval information for the selected SQM. Report interval settings are used to control the SQM to send readings out at a regular rate (in seconds) and only if darker than a specified threshold value. See section 8.8 on page 85 for more information about “Interval reporting”.




Figure 7.42: Report interval tab

Use the “R” button to temporarily set the value in to RAM for experimentation. The new value will be used instantly. The RAM value is set to the EEPROM value on power-up.

Use the “E/R” button to set the value in to EEPROM and RAM. The new value will be used instantly and also after power up.

Report interval is measured in seconds (i.e. 300 = 5 minutes).

Report threshold is measured in Magnitudes per square arcsecond (mpsas), a larger positive value is darker.

7.7.1 Continuous reports

The Continuous reports section enables special features related to reporting through an optionally installed I2C interface except for the Ideal crossover function selection.

Reporting enabled: The readings are sent to the I2C adapter as they are computed.

Reporting compressed: High speed reporting is sent out in a compressed format.

Report un-averaged: Send only the unaveraged readings to the I2C device.

LED blink accessory: Enables the LED on the DL models to blink each time a reading is gathered.

Ideal crossover firmware: See Theory of operation section 3.1 for full details.

7.8 Firmware tab

In a case where new firmware is supplied by Unihedron to correct bugs or add features, use this tab to select and load firmware in to the SQM-LL.

All available versions of firmware are shipped with the UDM software package in case you want to revert to an earlier firmware version for testing purposes. New firmware versions are announced on the Unihedron forum.




Figure 7.43: Firmware tab

Follow these steps to load new firmware:

1. Press the “Select Firmware” button to choose the firmware file to load in to the SQM as shown in Figure 7.44:




Figure 7.44: Firmware selection

2. Select the desired firmware file then press “Open”.
3. The “Load firmware” button will be enabled and you can press it now to start loading the firmware in to the SQM-LL. The status bar will indicate successful completion when the firmware has been completely loaded.

When using a Mac or Linux, the firmware can be loaded/restored using the “USB comm check” method when the associated buttons appear. The steps are shown as follows:

1. Start UDM
2. Have the meter connected
3. Go to the firmware tab
4. Select the appropriate firmware like SQM-LU-DL-4-6.67.hex
5. Press the "START UNPLUG METHOD button
6. Follow the instructions shown on the right side of the button.

7.9 Configuration tab

The “Configuration tab” shows the factory-set calibration values.

Calibration is performed at the Unihedron factory. A new calibration using a calibrated light source and darkroom can be performed by following the instructions on the right side of the screen. The calibration report can be logged to a data file and also printed out from this screen.




Figure 7.45: Configuration tab

Warning confirmations as shown in Figure 7.46 and Figure 7.47 are shown when trying to calibrate the unit yourself:




Figure 7.46: Light calibration confirmation




Figure 7.47: Dark calibration confirmation

7.9.1 Sensor arrangement

For documentation purposes, the SQM-LL can store information on the sensor arrangement (starting at firmware feature 35 and above). The type of Lensholder, Lens, and Filter can be defined.




Figure 7.48: Sensor arrangement

7.10 Simulation tab

The “Simulation” tab is enabled from the View menu.

The “Simulation” tab allows the simulation of raw light sensor values for experimentation purposes. The “Start” button initiates feeding the range of values to the internal formulas of the SQM-LL and results are displayed on this tab. Raw temperature conversions are detail in Eq: 8.1 and 8.2. The simulation will stop once all the steps are complete or when the “Stop” button is pressed.




Figure 7.49: Fig:Simulation tab

When using the Simulation mode of the SQM-LL, make sure that nothing else interrupts the sequence of readings such as external programs reading from the SQM-LL, or settings of Interval reporting inside the SQM-LL.

7.10.1 Simulation from file

The “From file” button sends csv data from `simin.csv` (in the log file directory) to the SQM-LL in simulation mode and puts the output into `simout.csv`. The format of the csv is shown in Table 7.5:

Table 7.5: simin.csv field description

| Position | Example value | Description |
|----------|---------------|--------------------|
| 1 | 3000 | Period in counts. |
| 2 | 30 | Frequency in Hz. |
| 3 | 20.3 | Temperature in °C. |

Listing 7.2: simin.csv example

```
0,568380,24.8
72970,6,13.2
```

The resultant output records will be shown on the screen and saved in `simout.csv` (in the log file directory) in the form of simulated result shown in section 8.9 as in the example shown in Listing 7.3:

Listing 7.3: simout.csv example

```
# Simulation from file.
# UDM version: 1.0.0.43
# Unit information cx: i,00000004,00000003,00000032,00000704
# Calibration cx: c,00000019.80m,0000107.511s, 028.3C,00000008.71m, 029.3C
S,0000000000c,0000568380f,0000000232t,r, 00.00m,0000568380Hz,0000000000c,0000000.000s, 024.8C
S,0000072970c,0000000006f,0000000196t,r, 17.79m,0000000006Hz,0000072970c,0000000.158s, 013.2C
```

7.10.2 Test response

The **Test resp.** button activates code to reset the SQM-LL then send multiple **r1x** commands. Watch the log for **,F** to see when the SQM-LL starts reporting fresh readings.

7.11 Accessory options

Some meters can be equipped/retro-fitted with optional accessories if they include firmware feature version ≥40.

See section 8.6 for details on the accessory commands.

The accessories tab (shown in 7.50) is available when selecting a device that has the appropriate firmware:




Figure 7.50: Accessories tab

7.11.1 Humidity accessory

There are currently two types of I²C humidity sensors that have been tested; HIH8120, and HYT939. The selection can be made with the drop down combo-box on this tab.

Enabling this sensor allows the SQM-LL to poll the sensor once per second to gather a reading which can be requested later with the A1x command.

The refresh button requests the most recent value that the SQM-LL has collected.

The Status field shows the status of the humidity sensor which is updated after the refresh button is pressed. The status is 'N/C' when the sensor is not connected.

7.11.2 Display accessory

A 4-digit 7-segment I²C display can be attached to the SQM-LL. Currently only the Sparkfun COM-11441 has been tested. This display shows the brightness reading in mpsas.

The brightness of the display can be fixed at a level between 0-7 (dimmest to brightest), or can be automatically dimmed in bright conditions (depending on the mpsas reading).

The display can be either updated periodically (1Hz) or whenever a reading request is made.

7.11.3 LED accessory

The LED indicator accessory is mainly used for troubleshooting to identify either when readings are created or requested. The LED blinks for 1/60th of a second.

The LED can blink either when the SQM-LL creates a reading, or when a reading is requested (using the rx command).

7.11.4 Relay accessory

The Relay accessory is mainly used for dew heater control. A 3.3V activated solid state relay can be connected directly to pin 23 of the micro-controller (25mA drive maximum).

When in Manual mode, the relay can be turned on or off.

When in Automatic mode, the relay is turned on when the mpsas reading is above the threshold and off when the mpsas reading is below the threshold.

Pressing the On/Off buttons while the relay is in automatic mode will switch it to manual mode.

7.12 Command line parameters

UDM can be started from the command line. Other stored parameters (like timezone) will be recalled automatically. Here is the summary of options:

Table 7.6: Log continuous command line parameters

| Parameter | Description |
|-----------|--|
| -LCMS,x | Every x seconds |
| -LCMM,x | Every x minutes |
| -LCM,1 | Every 1 minute on the minute |
| -LCM,5 | Every 5 minutes on the 1/12th hour |
| -LCM,10 | Every 10 minutes on the 1/6th hour |
| -LCM,15 | Every 15 minutes on the 1/4 hour |
| -LCM,30 | Every 30 minutes on the 1/2 hour |
| -LCM,60 | Every hour on the hour |
| -LCR | Start recording right away |
| -LCMIN | Minimize Application after Log continuous window starts up |
| -LCTH,x | Threshold setting. Readings equal to or greater than x (in mpsas) get recorded. If x=0 then all readings are get recorded. |
| -LCGRS | Run GoTo script then shut down when done |

Table 7.7: Select device command line parameters

| Parameter | Description |
|--------------|--|
| -SEI,x | Select Ethernet device where x = IP address |
| -SEM,x | Select Ethernet device where x = MAC address |
| -SUC,x | Select USB device where x = communication port-name i.e. /tty/USB0 |
| -SUI,x[,...] | Select USB device where x = ID number ex FTD12345, or multiple IDs for LogContinuous with the first one being the priority set like: -SUI,FTD12345,FTD33333,FTD55555 |

Table 7.8: Select features command line parameters

| Parameter | Description |
|-----------|--|
| -N | Do not search for devices at startup. This cuts down startup time, the user must press the Find button to find devices. |
| -P | Display plotter window. |
| -TCA | Start up Concatenate/Analyze tool |
| -TCM | Start up Cloud removal / Milky way position tool |

Table continued on next page ...

Table 7.8 – *continued from previous page*

| Parameter | Description |
|-----------|--|
| -TCMR | Start up Cloud removal / Milky way position tool, and recall previous filename |

7.12.1 Internal startup options

UDM also has the ability to store the startup options internally so that no extra command line parameters are required. You can access this setting from **File** → **Startup options** menu.

7.12.2 Windows autostartup

To get Windows to open up UDM at startup:

- Select the Start button and scroll to find the Unihedron Device Manager app that you want to run at startup.
- Right-click the app, select More, and then select Open file location. This opens the location where the shortcut to the app is saved. If there isn't an option for Open file location, it means the app can't run at startup.
- With the file location open, press the Windows logo key + R, type shell:startup, then select OK. This opens the Startup folder.
- Copy and paste the shortcut to the app from the file location to the Startup folder.

To get UDM to start the log continuous feature when starting up:

- Make sure that you already tested the Log Continuous feature so that it works correctly.
- Press the Windows logo key + R, type shell:startup, then select OK.
- Right click on the UDM icon that should have been there from the above steps
- Show more options, then press Properties
- Edit the TARGET to put double quote marks around the executable, but do not change the text, and add a space and then **-LCR** to end. It will look something like this:
"C:\Users\User\AppData\Local\Unihedron\udm.exe" -LCR

Note: If you have more than one device that UDM finds, then it will be important to identify that device on startup, for example like this example to find the USB device with USB ID 12345678 and starts logging to disk:

"C:\Users\User\AppData\Local\Unihedron\udm.exe" -SUI,12345678 -LCR

Note: You can leave out the above optional parameters from the command line if you include those in the internal startup options in the UDM **File** → **Startup options** menu.

7.12.3 Windows scheduled startup

In Windows, you can use the **Task Scheduler** to start and stop recording.

First make sure that UDM can read your meter and can log data using the Log Continuous feature. Also, use UDM to determine the MAC address of the meter (on the main page). Then, close UDM.

Enter the start/stop times into the Windows Task Scheduler. Start the task scheduler as follows:

1. Click the Windows "Start" button
2. Start typing Schedule Tasks
3. Select the Schedule Tasks or Task Scheduler program.

Then:

1. Press "Create basic task" on the right side in the Actions window.
2. Name: Start UDM
3. Next
4. Daily
5. Enter the desired start time
6. Select Start a program
7. Click on browse to find the program which is usually located at "C:\Users\User\AppData\Local\Programs\Unihedron\udm.exe"
8. For SQM-LE, Enter additional parameter: **-SEM,x -LCM,y -LCR**
where **x** is the MAC address of the SQM-LE to be monitored, for example: 00204AAF20A2
where **y** is the number of minutes between recordings, for example: 5
For SQM-LU, Enter additional parameter: **-SUC,x -LCM,y -LCR**
where **x** is the MAC address of the SQM-LU to be monitored, for example: COM1
where **y** is the number of minutes between recordings, for example: 5
More command line definitions found in **UDM->Help->Command line information**
9. Next, Finish

Tasks may not show up in the Task Scheduler library immediately, you may have to close the Task scheduler and restart it.

Then, make another task to stop UDM at a specific time as follows:

1. Press "Create basic task" on the right side in the Actions window.
2. Name: Stop UDM
3. Next
4. Daily
5. Enter the desired stop time
6. Select Start a program
7. Type the following into the program area: taskkill
8. Enter additional parameters: /IM udm.exe /F
9. Next, Finish

The logged files are stored in your log directory, usually located at: "C:\ProgramData\Unihedron\logs"
The above was tested with Windows 10 and UDM ver.105.

7.12.4 Mac autostartup

You can have UDM start up when you login to your Mac. Enter your UDM startup parameters in the UDM File -> Startup options menu. Then add UDM to the Mac Login items as follows:

- Go to System Preferences > Users & Groups from the main Mac menu.
- Select your user account in the list on the left
- Click Login Items.
- Click the Add button.
- Select UDM from the Applications folder.

8 Commands and responses

The SQM-LL accepts a sequence of characters as a command, then executes those commands and usually provides a response of a sequence of characters. The following details are useful when programming your own interface to send data to and receive data from the SQM-LL.

8.1 Commands

Commands consist of a string of characters. The first character is the command type. The following is a list of the “Standard” commands:

Table 8.1: Summary of standard commands

| Command | Description |
|----------------------|---|
| rx r1x Rx R1x | Reading request (averaged). |
| ux u1x Ux U1x | Unaveraged reading requests. |
| rfx rFx | Linear, Inline linear reading requests. |
| cx | Calibration information request. |
| ix | Unit information request (note lower case “i”). |
| zcalAx | Arm Light Calibration command. |
| zcalBx | Arm Dark Calibration command. |
| zcalDx | Disarm Calibration command. Also reports the <code>lock</code> switch status. |
| zcal5 | Manually Set Light Calibration Offset. |
| zcal6 | Manually Set Light Calibration Temperature. |
| zcal7 | Manually Set Dark Calibration Time Period. |
| zcal8 | Manually Set Dark Calibration Temperature. |
| 0x19 | Reset micro-controller. Hexadecimal value 19. See the “Firmware Upgrade” chapter on page 92 for more details. |
| : | Intel Hex firmware upgrade initiation. See the “Firmware Upgrade” chapter on page 92 for more details. |
| P...x | Set period (in seconds) for interval reporting to EEPROM and RAM for booting and immediate use. Firmware feature=13. |
| p...x | Set period (in seconds) for interval reporting to RAM for immediate use. Firmware feature=13. |
| T...x | Set threshold (in $\frac{mag}{arcsec^2}$) for interval reporting only to EEPROM and RAM for booting and immediate use. Firmware feature \geq 13. |
| t...x | Set threshold (in $\frac{mag}{arcsec^2}$) for interval reporting only to RAM for immediate use. Firmware feature \geq 13. |
| Ix | Request interval settings (note upper case “I”). Firmware feature \geq 13. |
| sx | Request reading of internal variables. |
| S...x | Simulate internal calculations. |

8.2 Response details

8.2.1 Reading request

The “Reading” request “rx” or “Rx” commands the SQM-LL to provide the current darkness value as well as all variables used to generate that result.

Readings produced by this request are averaged internally by using the last 8 readings and shifting those values through an 8 cell buffer then summing and dividing by 8. Use the “ux” command to get the un-averaged and most recent value. Averaging is only performed on period-mode readings (when the light sensor frequency is below 128Hz). Frequency mode readings (above 128Hz) are automatically averaged because the reading is taken from a one second sampling of pulses.

The format of the rx response is shown in table 8.2:

Table 8.2: rx Reading request response

| Column | Example value | Description |
|--------|---------------------|--|
| 0 | r | Indicates that a reading is being returned. |
| 2-8 | _06.70m | Reading in $\frac{mag}{arcsec^2}$. Leading space for positive value. Leading negative sign (-) for negative value. A reading of 0.00m means that the light at the sensor has reached the upper brightness limit of the unit. |
| 10-21 | 0000022921Hz | Frequency of sensor in Hz. |
| 23-33 | 0000000020c | Period of sensor in counts. Counts occur at a rate of 460.8 kHz (14.7456MHz/32). |
| 35-46 | 0000000.000s | Period of sensor in seconds with millisecond resolution. Determined by dividing the above counts value by 460800. |
| 48-54 | _039.4C | Temperature measured at light sensor in degrees C. The value is averaged and presented every 4.3 seconds. Leading space for positive value. Leading negative sign (-) for negative value. |
| 55-56 | C L R F | Carriage return (0x0d), Line feed (0x0a). |

An example of the response is:

**r, 06.70m,0000022921Hz,0000000020c,0000000.000s, 039.4C_R_F
0123456789 123456789 123456789 123456789 123456789 123456789 123456**

Future versions of this reading string will only modify reported values beyond position 54. Characters 0 to 54 may be considered stable.

A special case “Rx” command returns the serial number in the same format as the interval report does. See page 85 “Setting Interval reporting parameters” for report details.

To include the “Freshness” status, use the “r1x” command. The response is shown in table 8.3

Table 8.3: r1x Reading request response

| Column | Example value | Description |
|--------|---------------------|---|
| 0 | r | Indicates that a reading is being returned. |
| 2-8 | _06.70m | Averaged reading in $\frac{mag}{arcsec^2}$. Leading space for positive value. Leading negative sign (-) for negative value. A reading of 0.00m means that the light at the sensor has reached the upper brightness limit of the unit. |
| 10-21 | 0000022921Hz | Frequency of sensor in Hz. |
| 23-33 | 0000000020c | Period of sensor in counts. Counts occur at a rate of 460.8 kHz (14.7456MHz/32). |
| 35-46 | 0000000.000s | Period of sensor in seconds with millisecond resolution. Determined by dividing the above counts value by 460800. |

Table continued on next page ...

Table 8.3 – *continued from previous page*

| Column | Example value | Description |
|--------|-----------------------|--|
| 48-54 | <u>-039.4C</u> | Temperature measured at light sensor in degrees C. The value is averaged and presented every 4.3 seconds. Leading space for positive value. Leading negative sign (-) for negative value. |
| 56-72 | <u>-06.53m</u> | Unaveraged reading in $\frac{mag}{arcsec^2}$. Leading space for positive value. Leading negative sign (-) for negative value. A reading of 0.00m means that the light at the sensor has reached the upper brightness limit of the unit. |
| 74 | F | Freshness state, either: F: fresh FREQUENCY mode reading. P: fresh PERIOD mode reading. S: STALE reading indicates that this reading has not changed since the last reading because there was not enough light gathered to produce a new reading. |
| 75-76 | C L R F | Carriage return (0x0d), Line feed (0x0a). |

An example of the response is:

r, 06.70m,0000022921Hz,0000000020c,0000000.000s, 039.4C, 06.53m, F_{RF}
0123456789 123456789 123456789 123456789 123456789 123456789 123456789 123456789

The **r1x** request response is the same as **rx**, with the freshness status of Frequency/Period/Stale (,F ,P ,S) appended

The **Rx** request response is the same as **rx**, with the serial number appended.

The **R1x** request response is the same as **rx**, with freshness status of Frequency/Period/Stale (, **F** , **P** , **S**), and the serial number appended.

8.2.2 Unaveraged reading request

The “unaveraged reading” request **ux** commands the meter to provide the current darkness value as well as all variables used to generate that result. This readings is not averaged out like the **rx** command.

The format of the **ux** response is shown in table 8.4:

Table 8.4: Unaveraged reading request response

| Column | Example value | Description |
|--------|---------------------|---|
| 0 | u | Indicates that a reading is being returned. |
| 2-8 | -06.70m | Averaged Reading in $\frac{\text{mag}}{\text{arcsec}^2}$. Leading space for positive value. Leading negative sign (-) for negative value. A reading of 0.00m means that the light at the sensor has reached the upper brightness limit of the unit. |
| 10-21 | 0000022921Hz | Frequency of sensor in Hz. |
| 23-33 | 0000000020c | Unaveraged Period of sensor in counts. Counts occur at a rate of 460.8 kHz (14.7456MHz/32). |

Table continued on next page ...

Table 8.4 – *continued from previous page*

| Column | Example value | Description |
|--------|---------------------|---|
| 35-46 | 0000000.000s | Unaveraged period of sensor in seconds with millisecond resolution. Determined by dividing the above counts value by 460800. |
| 48-54 | -039.4C | Unaveraged temperature measured at light sensor in degrees C. The value is presented every 4.3 seconds. Leading space for positive value. Leading negative sign (-) for negative value. |
| 55-56 | CR | Carriage return (0xd), Line feed (0xa). |

An example of the response is:

u, 06.70m,0000022921Hz,0000000020c,0000000.000s, 039.4CRL
0123456789 123456789 123456789 123456789 123456789 123456

The **u1x** request response is the same as **ux**, with the unaveraged reading, and the freshness status of Frequency/Period/Stale (,F ,P ,S) appended.

The **Ux** request response is the same as **ux**, validity/invalidity (,V ,I) appended.

The **U1x** request response is the same as **ux**, with the unaveraged reading, and the freshness status of Frequency/Period/Stale (,F ,P ,S) appended.

8.2.3 Linear reading request

The “linear reading” request “rfx” commands the meter to provide the current brightness value proportional to the light flux or frequency output from the light sensor. This value is compensated for only by the dark current frequency.

$$f_{out} = f_{light} - f_{dark}$$

To allow for long period measurements, the output integer value is scaled up by a factor of 45,000.

$$n_{out} = f_{out} \times 45000$$

The format of the response is shown in table 8.5:

Table 8.5: Linear reading request response

| Column | Example value | Description |
|--------|-------------------|--|
| 0-1 | f, | Indicates that a frequency reading is being returned. |
| 2-11 | 0001287103 | Frequency reading. A reading of 0000045000 would indicate a sensor frequency of 1Hz, but the meter limits to 25kHz for later scaling of snow factor, so the maximum value would be 1125045000 (25kHz × 45000). A reading of 0000000000 would indicate total darkness, but the meter limits time readings to 85 seconds maximum, so the darkest value would be 0000000529 ($\frac{1}{85s} \times 45000$). |
| 12-13 | CR | Carriage return (0xd), Line feed (0xa). |

An example of the response is:

f,0001287103RL
0123456789 123

8.2.4 Inline linear reading request

The “inline linear reading” request “rFx” (note: capital F) commands the meter to include the the current brightness value proportional to the light flux or frequency output from the light sensor. This value is compensated for only by the dark current frequency.

$$f_{out} = f_{light} - f_{dark}$$

To allow for long period measurements, the output integer value is scaled up by a factor of 45,000.

$$n_{out} = f_{out} \times 45000$$

The format of the response is similar to the “rx” response and is shown in table 8.6:

Table 8.6: Inline linear reading request response

| Column | Example value | Description |
|--------|---------------------|---|
| 0 | r | Indicates that a reading is being returned. |
| 2-8 | 06.70m | Reading in $\frac{mag}{arcsec^2}$. Leading space for positive value. Leading negative sign (-) for negative value. A reading of 0.00m means that the light at the sensor has reached the upper brightness limit of the unit. |
| 10-21 | 0000022921Hz | Frequency of sensor in Hz. |
| 23-33 | 0000000020c | Period of sensor in counts. Counts occur at a rate of 460.8 kHz (14.7456MHz/32). |
| 35-46 | 0000000.000s | Period of sensor in seconds with millisecond resolution. Determined by dividing the above counts value by 460800. |
| 48-54 | 039.4C | Temperature measured at light sensor in degrees C. The value is averaged and presented every 4.3 seconds. Leading space for positive value. Leading negative sign (-) for negative value. |
| 56-65 | 0001287103 | Frequency reading. A reading of 0000045000 would indicate a sensor frequency of 1Hz, but the meter limits to 25kHz for later scaling of snow factor, so the maximum value would be 1125045000 (25kHz \times 45000). A reading of 0000000000 would indicate total darkness, but the meter limits time readings to 85 seconds maximum, so the darkest value would be 0000000529 ($\frac{1}{85s} \times 45000$). |
| 66-67 | LF | Carriage return (0xd), Line feed (0xa). |

An example of the response is:

r, 06.70m,0000022921Hz,0000000020c,0000000.000s, 039.4C,0001287103LF
0123456789 123456789 123456789 123456789 123456789 123456789 1234567

8.2.5 Unit information

Unit information command “ix” provides details about the software in the micro-controller.

The format of the response is:

Table 8.7: Unit information request response

| Column | Example value | Description |
|--------|-----------------|--|
| 0 | i | Indicates that the unit information response is being returned. |
| 2-9 | 00000002 | Protocol number (8 digits). This will always be the first 8 characters (after the “i,” response). This value indicates the revision number of the data protocol to/from the SQM-LL. The protocol version is independent of the feature version. |
| 11-18 | 00000003 | Model number (8 digits). The model value identifies the specific hardware model that the firmware is tailored for. |
| 20-27 | 00000001 | Feature number (8 digits). The feature value identifies software features. This number is independent of the data protocol. |
| 29-36 | 00000413 | Serial number (8 digits). Each unit has its own unique serial number. |
| 37-38 | CL | Carriage return (0xd), Line feed (0xa). |

An example of the response is:

i,00000002,00000003,00000001,00000413CL
0123456789 123456789 123456789 12345678

8.3 Calibration commands

8.3.1 Calibration information request

The calibration information request “cx” returns all data about the specific light sensor in the unit required to calculate a reading.

The format of the response is shown in table 8.8:

Table 8.8: Calibration information request response

| Column | Example value | Description |
|--------|---------------------|---|
| 0 | c | Indicates that the calibration information is being returned. |
| 2-13 | 00000017.60m | Light calibration offset in $\frac{\text{mag}}{\text{arcsec}^2}$. |
| 15-26 | 0000000.000s | Dark calibration time period in seconds with millisecond resolution. |
| 28-34 | -039.4C | Temperature in degrees C measured during light calibration. Leading space for positive value. Leading negative sign (-) for negative value. |
| 36-47 | 00000008.71m | Offset of light sensor in $\frac{\text{mag}}{\text{arcsec}^2}$ based on manufacturing reference. The factory calibration light source is equivalent to 8.71 $\frac{\text{mag}}{\text{arcsec}^2}$, and when the “Light calibration” button is pressed in UDM, the meter creates the light calibration offset value (17.60 in this case) so that the meter reads 8.71 also. |
| 49-55 | -039.4C | Temperature in degrees C measured during dark calibration. Leading space for positive value. Leading negative sign (-) for negative value. |
| 56-57 | CL | Carriage return (0xd), Line feed (0xa). |

An example of the response is:

**c,00000017.60m,0000000.000s, 039.4C,00000008.71m, 039.4C_{RF}
0123456789 123456789 123456789 123456789 123456789 1234567**

8.3.2 Light calibration command

Calibration of the SQM-LL is done at the factory in a controlled light and temperature environment.

Executing the Light calibration command “zcalAx” arms the light calibration mode.

A calibrated light source of approximately 13.5fc is supplied to the sensor.

The format of the response is shown in table 8.9:

Table 8.9: Light calibration response

| Column | Example value | Description |
|--------|-----------------------|--|
| 0 | z | Indicates that a “Calibration” response is being returned. |
| 1 | A | Indicates Light Calibration mode. |
| 2 | a | Indicates that the calibration is armed. |
| 3 | L | L = Locked; Wait for unlock before calibrating after Arm command, firmware upgrades are disabled. U = Unlocked; Calibrate immediately after Arm command, Enable firmware upgrade. |
| 4-5 | C_{LF} | Carriage return (0x0d), Line feed (0x0a). |

An example of the response is:

**zAaL_{RF}
012345**

8.3.3 Dark calibration command

Dark Calibration is done at the factory along with Light calibration and calibration temperature recording.

Executing the dark calibration command “zcalBx” arms the dark calibration mode.

Dark calibration is performed in a completely dark environment. Check a reading to ensure that the period is correct after entering the dark environment, it could take a few minutes to collect an accurate dark period. A dark period of only a few seconds is too small.

The format of the response is shown in table 8.10:

Table 8.10: Dark calibration response

| Column | Example value | Description |
|--------|---------------|--|
| 0 | z | Calibration response is being returned. |
| 1 | B | Dark Calibration. |
| 2 | a | Armed. |
| 3 | L | L = Locked; Wait for unlock before calibrating after Arm command, firmware upgrades are disabled. U = Unlocked; Calibrate immediately after Arm command, Enable firmware upgrade. |

| | | |
|-----|--------------------------|---|
| 4-5 | C L R F | Carriage return (0x0d), Line feed (0x0a). |
|-----|--------------------------|---|

An example of the response is:

zBaL
C L
R F
012345

8.3.4 Disarm calibration command

The Disarm calibration command “**zcalDx**” disarms calibration modes from being triggered by the unlock mode.

The format of the response is shown in table 8.11:

Table 8.11: Disarm calibration response

| Column | Example value | Description |
|--------|--------------------------|--|
| 0 | z | Calibration response is being returned. |
| 1 | x | Indicates “All” calibration modes. |
| 2 | d | Disarmed. |
| 3 | L | L = Locked; Wait for unlock before calibrating after Arm command, firmware upgrades are disabled. U = Unlocked; Calibrate immediately after Arm command, Enable firmware upgrade. |
| 4-5 | C L R F | Carriage return (0x0d), Line feed (0x0a). |

An example of the response is:

zxdL
C L
R F
012345

8.3.5 Manually set light calibration offset

Calibration is done at the factory, however, in the case where calibration values must be restored or set to something else, this command allows a new calibration value to be placed into the meter.

Executing the command “**zcal15#####.##x**” manually sets the light calibration offset to the value specified in “#####.##”. The units are $\frac{\text{magnitudes}}{\text{arcsecond}^2}$.

The format of the response is shown in table: 8.12:

Table 8.12: Response for manual setting of light calibration offset

| Column | Example value | Description |
|--------|--------------------------|---|
| 0 | z | Calibration response is being returned. |
| 2 | 5 | Manual Set Light Calibration Offset |
| 4-15 | 00000017.60m | Value that was set into EEPROM |
| 16-17 | C L R F | Carriage return (0x0d), Line feed (0x0a). |

An example of the response is:

z,5,00000017.60m
C L
0123456789 1234567

8.3.6 Manually set light calibration temperature

Calibration is done at the factory, however, in the case where calibration values must be restored or set to something else, this command allows a new calibration value to be placed into the meter.

The “Light calibration temperature” is the temperature of the meter when the meter was calibrated for its “Light calibration offset”.

Executing the command “zcal6#####.##x” manually sets the light calibration temperature to the value specified in “#####.##”. The units are °C.

Note: The meter records the temperature in a raw value with different resolution, so the reply back may not be exactly the same as the value sent.

The format of the response is shown in table: 8.13:

Table 8.13: Response for manually setting of light calibration temperature

| Column | Example value | Description |
|--------|---------------|---|
| 0 | z | Calibration response is being returned. |
| 2 | 6 | Manual Set Light Calibration Offset |
| 4-9 | 019.00 | Value that was set into EEPROM |
| 10-11 | CR | Carriage return (0xd), Line feed (0xa). |

An example of the response is:

z,6,019.00CR
0123456789 1

8.3.7 Manually set dark calibration time period

Calibration is done at the factory, however, in the case where calibration values must be restored or set to something else, this command allows a new calibration value to be placed into the meter.

The “Dark calibration time period” is the amount of time that has elapsed for the light sensor to make one cycle while in complete darkness. The meter sets a time limit of 300 seconds on this value.

Executing the command “zcal7#####.##x” manually sets the light calibration offset to the value specified in “#####.##”. The units are in seconds.

The format of the response is shown in table: 8.14:

Table 8.14: Response of manually setting dark calibration time period

| Column | Example value | Description |
|--------|---------------------|--|
| 0 | z | Calibration response is being returned. |
| 2 | 7 | Manual Set Dark Calibration time period. |
| 4-15 | 0000300.000s | Value that was set into EEPROM |
| 16-17 | CR | Carriage return (0xd), Line feed (0xa). |

An example of the response is:

z,7,0000300.000sCR
0123456789 1234567

8.3.8 Manually set dark calibration temperature

Calibration is done at the factory, however, in the case where calibration values must be restored or set to something else, this command allows a new calibration value to be placed into the meter.

The “Dark calibration temperature” is the temperature of the meter when the meter was calibrated for its “Dark calibration time period”.

Executing the command “**zcal8#####.##x**” manually sets the light calibration offset to the value specified in “**#####.##**”. The units are °C.

Note: The meter records the temperature in a raw value with different resolution, so the reply back may not be exactly the same as the value sent.

The format of the response is shown in table: 8.15:

Table 8.15: Response for manually setting of dark calibration temperature

| Column | Example value | Description |
|--------|---------------|--|
| 0 | z | Calibration response is being returned. |
| 2 | 8 | Manual Set Dark Calibration temperature. |
| 4-9 | 019.0C | Value that was set into EEPROM |
| 10-11 | CR | Carriage return (0xd), Line feed (0xa). |

An example of the response is:

z,8,019.0C_{RF}
0123456789 1

8.4 Lock settings

Firmware feature ≥ 46 allows fine control of how the lock switch operates.

It is recommended that all changes be made with the lock switch in the unlocked position otherwise the "these settings" set to true will render other settings unchangeable.

The command Kx will return the status of the Lock settings (see response below).

Table 8.16: Lock setting command summary

| Command | Description |
|------------------|--|
| Kx | Report the Lock setting status. |
| K _m x | Change the Lock setting (where $m=C,c,R,r,G,g,T,t$) as follows: C = Calibration changes respect the lock setting. c = Calibration changes ignore the lock setting. R = Report Interval changes respect the lock setting. r = Report Interval ignore the lock setting. G = Configuration changes respect the lock setting. g = Configuration changes ignore the lock setting. T = These setting changes respect the lock setting. t = These setting changes ignore the lock setting. |

Table 8.17: Lock setting response summary

| Position | Example value | Description |
|----------|---------------|---|
| 0 | K, | Confirmation of Lock setting command. |
| 1 | m | C = Calibration changes respect the lock setting. c = Calibration changes ignore the lock setting. |
| 2 | m | R = Report Interval changes respect the lock setting. r = Report Interval ignore the lock setting. |
| 3 | m | G = Configuration changes respect the lock setting. g = Configuration changes ignore the lock setting. |
| 4 | m | T = These setting changes respect the lock setting. t = These setting changes ignore the lock setting. |

An example response to "Kx" is:

K,crGT

8.4.1 Checking lock status

Use the `zcalDx` command to determine if the lock switch is in Locked or Unlocked position.

The response contains an L for locked, or U for unlocked. Other text may be present, check the `zcal` command for details.

8.5 Snow LED accessory

An LED used for determining snow cover on the meter can be attached to an internal pin of the SQM-LL. This LED shines green light out of the meter and the light sensor will see a reflection if snow is covering the meter (housing cap). The light meter reading will be unchanged with no snow present, and about $1.6 \frac{mag}{arcsec^2}$ brighter with snow cover present.

Table 8.18: Snow LED accessory command summary

| Command | Description |
|---------|--|
| A50x | Turn off the Snow LED accessory. |
| A51x | Turn on the Snow LED accessory. |
| A5ex | Enable Snow LED logging (while on battery power). |
| A5dx | Disable Snow LED logging (while on battery power). |
| A5x | LED accessory status. |

Table 8.19: Snow LED accessory response summary

| Position | Example value | Description |
|----------|---------------|---|
| 0-2 | A5, | Confirmation Snow LED accessory command. |
| 3 | n | Where $n = 0$ indicates the Snow LED is Off. 1 indicates the Snow LED is On. |
| 4 | m | Where $m = 0$ indicates the Snow LED is disabled. 1 indicates the Snow LED is enabled. |
| 5-6 | CR LF | Carriage return (0xd), Line feed (0xa). |

An example response to “A5x” is:

**A5,01CR
LF
0123456**

8.6 Accessories commands

Some I²C accessory devices can be connected to the SQM-LL when using firmware feature version 44 and above. These devices are connected by way of retrofitted wiring inside the unit or a future back panel connector.

All of the SQM-LL accessory commands begin with “A” (upper case).

8.6.1 Humidity / Temperature sensor

Two I²C humidity/temperature sensors models can be connected to the SQM-LL. All commands (seen in table 8.20) to this accessory result in a response (seen in table 8.21).

Table 8.20: Humidity/temperature command summary

| Command | Description |
|---------|--|
| A1Ex | Enable the humidity temperature accessory. |
| A1Dx | Disable the humidity temperature accessory. |
| A1Mmx | Set the model number (where $m=0-7$) of the the humidity temperature accessory: 0=HIH8120 1=HYT939 (Sold by ControlEverything and others) |
| A1x | Report on the humidity temperature status. |

Table 8.21: Humidity/temperature response summary

| Position | Example value | Description |
|----------|------------------|--|
| 0 | A, 1, | Confirmation of humidity/temperature accessory command. |
| 1 | 1, | Accessory 1 (Humidity/temperature sensor). |
| 2 | e, | E for enabled. D for disabled. |
| 3 | m, | Model number (where $m=0-7$): 0=HIH8120 1=HYT939 (Sold by ControlEverything and others) |
| 4 | s | Status (0-3). 0 = Normal Operation, Valid Data that has not been fetched since the last measurement cycle. 1 = Stale Data: Data that has already been fetched since the last measurement cycle, or data fetched before the first measurement has been completed. 2 = Sensor in Command Mode. 3 = Not used. |
| 5 | nnnnn | Humidity(%RH) = $\frac{nnnnn}{2^{14}-2} \times 100\%$. 16383 when no connection. |
| 6 | nnnnn | Temperature(°C) = $\frac{nnnnn}{2^{14}-2} \times 165 - 40$. 16383 when no connection. |
| | CL RF | Carriage return (0xd), Line feed (0xa). |

An example response to “A1x” is:

A,1,E,1,0,07788,06202CL

8.6.2 Display accessory

An I²C 4-digit 7-segment display made by Sparkfun (model COM-11441) can be connected. All commands (seen in table 8.22) to this accessory result in a response (seen in table 8.23).

Readings that are too bright for the SQM-LL will show up as □ □ □□. Readings that are too dark for the meter will show up as □ □ □□.

Table 8.22: Display accessory command summary

| Command | Description |
|--------------|---|
| A2Ex | Enable the display accessory. |
| A2Dx | Disable the display accessory. |
| A2Fx | Fixed mode of brightness. |
| A2Ax | Auto mode of brightness. Lowers brightness on dark nights. Display at lowest brightness (30%) when greater than 19.00mpsas. Display at medium brightness (50%) between 17.00 to 19.00mpsas. Display at full brightness (100%) when less than 17.00mpsas. |
| A2Mnx | Set the model of display (where $n = 0-3$). |
| A2Vnx | Set the fixed mode brightness (where $n = 0-7$). |
| A2Px | Set the updating mode to periodically updating at 1Hz. |
| A2Rx | Set the updating mode to updating when reading request is made. |
| A2x | Report on the display status. |

Table 8.23: Display accessory response summary

| Position | Example value | Description |
|----------|------------------|--|
| 0 | A, | Confirmation of display accessory command. |
| 1 | 2, | Accessory 2 (Display). |
| 2 | e, | E for enabled. D for disabled. |
| 3 | m, | Model number (where $m = 0-3$). |
| 4 | m, | F=Fixed mode. A=Auto mode. See table 8.22 for description. |
| 5 | n, | Fixed brightness level (where $n = 0-7$). |
| 6 | m | P = periodically updating at 1Hz R = updating when reading request is made. |
| | CL RF | Carriage return (0xd), Line feed (0xa). |

An example response to “A2x” is:

A,2,E,0,F,2,R_{RF}^{CL}

8.6.3 LED accessory

For purposes of troubleshooting, an LED with series resistor can be connected to an internal pin of the SQM-LL. All commands (seen in table 8.24) to this accessory result in a response (seen in table 8.25).

Using the LED to indicate when a reading is being requested is an ideal method to determine if the controlling software is actually accessing the SQM-LL.

Table 8.24: LED accessory command summary

| Command | Description |
|---------|--|
| A3Ex | Enable the LED accessory. |
| A3Dx | Disable the LED accessory. |
| A30x | Mode=Blink at reading creation. In bright sky conditions, readings are created once per second in frequency-mode. In darker sky conditions, the meter goes into perdioid-mode starting at 679Hz and lower, and LED will blink at a variable rate. |
| A31x | Mode=Blink at reading request. |
| A3x | LED accessory status. |

Table 8.25: LED accessory response summary

| Position | Example value | Description |
|----------|---------------|--|
| 0 | A , | Confirmation of display accessory command. |
| 1 | 3 , | Accessory 3 (LED). |
| 2 | e , | E for enabled. D for disabled. |
| 3 | m , | Model number (where $m = 0-7$). 0 = LED connected to pin-13 through 1k resistor to ground. |
| 4 | m , | Mode of operation (where $m = 0-1$): 0 = Blink at reading creation. 1 = Blink at reading request. |
| | CR | Carriage return (0x0d), Line feed (0x0a). |

An example response to “A2x” is:

A,3,E,0,1CR

8.6.4 Relay accessory

A Solid State Relay (SSR) accessory may be connected to the SQM-LL for generic use or for purposes of implementing a dew-heater control. All commands (seen in table 8.26) to this accessory result in a response (seen in table 8.27).

Table 8.26: Relay accessory command summary

| Command | Description |
|---------------|--|
| A4x | Get status of the relay accessory. |
| A40x | Deactivate the relay accessory. Also places the accessory into manual mode. |
| A41x | Activate the relay accessory. Also places the accessory into manual mode. |
| A4Mnx | Set the mode of operation: 0=Light threshold activated. 1=Dewpoint activation. 2=Heat activated. 3-6=future use. 7=Manual mode where only the A40x and A41x commands affect the relay activation. |
| A4Tnnx | Set the darkness threshold for relay activation. Where <i>nn</i> is the the darkness threshold. The relay will be activated above this threshold. Monitoring is performed once per second. |

Table 8.27: Relay accessory response summary

| Position | Example value | Description |
|----------|---------------|---|
| 0 | A, | Confirmation of display accessory command. |
| 1 | 4, | Accessory 3 (relay). |
| 2 | s, | Status of device: 0 for deactivated relay. 1 for activated relay. |
| 3 | m, | Mode of operation (where <i>m</i> =0-7): 0 = Light mode. 1 = Dewpoint mode. 2 = Heat mode. 7 = Manual mode. |
| 4 | nn | Threshold of darkness (in mpsas) for automatic mode of operation. |
| 5 | ttt | Temperature (°C) used for dewpoint calculation. |
| 6 | hhh | Humidity (%RH) used for dewpoint calculation. |
| 7 | ddd | Dewpoint temperature (°C) used for dewpoint calculation. |
| | CR | Carriage return (0xd), Line feed (0xa). |

An example response to “A2x” is:

A,4,1,2,15,10,50,40,0CR

8.7 Continuous reporting commands

The Continuous reporting features are somewhat experimental. A description of each feature follows:

Table 8.28: Summary of standard commands

| Option | Description |
|--------------------------|---|
| Reporting enabled | Send a reading result every time it is available from internal computations. In bright settings, a reading will be made available once per second, around 14mpsas, a reading will be available depending on the sensor response which is between 60+ times per second and 60 seconds in very dark settings. |
| Ideal crossover firmware | Changes the crossover of reporting from original (around 15mpsas to 12.32mpsas which results in better resolution across the entire range of possible readings. |
| Reporting compressed | Send the above enabled reading out in a compressed format without extra text. |
| Report un-averaged | Sends the above reading out from the un-averaged accumulator. Normally the averaged reading is sent. |

Table 8.29: Continuous reporting command summary

| Command | Description |
|------------|--|
| Yx | Get status of the continuous reporting features. |
| YRx | Enable continuous reporting. |
| Yrx | Disable continuous reporting. |
| YCx | Enable ideal crossover firmware code. |
| Ycx | Disable ideal crossover firmware code. |
| YPx | Enable continuous reporting compression. |
| Ypx | Disable continuous reporting compression. |
| YUx | Enable un-averaged continuous reporting. |
| Yux | Disable un-averaged continuous reporting. |

Table 8.30: Response of all continuous reporting requests

| Column | Example value | Description |
|--------|---------------|---|
| 0 | Y | Confirmation of command. |
| 1 | r | R = Continuous reporting enabled. r = Continuous reporting disabled. |
| 2 | c | C = Ideal crossover firmware code enabled. c = Ideal crossover firmware code disabled. |
| 3 | p | P = Continuous reporting compression enabled. p = Continuous reporting compression disabled. |
| 4 | u | U = Continuous reporting un-averaged readings enabled. u = Continuous reporting un-averaged readings disabled. |

Table continued on next page ...

Table 8.30 – *continued from previous page*

| Column | Example value | Description |
|--------|--------------------|---|
| 5-6 | C L R F | Carriage return (0x0d), Line feed (0x0a). |

An example response is:

YrCpu
0123456

8.8 Setting Interval reporting parameters

For firmware feature ≥ 13 , the SQM-LL is capable of sending timed interval reports. Each interval report is the same as the reading request report except that the serial number (feature ≥ 14) is attached at the end so that numerous reporting SQM-LLs can be distinguished from each other.

The format of the interval report is shown in table 8.31:

Table 8.31: Interval report

| Column | Example value | Description |
|--------|---------------------|---|
| 0 | r | Indicates that a reading is being returned. |
| 2-8 | -06.70m | Reading in magnitudes per square arc second. Leading space for positive value. Leading negative sign (-) for negative value. A reading of 0.00m means that the light at the sensor has reached the upper brightness limit of the unit. |
| 10-21 | 0000022921Hz | Frequency of sensor in Hz. |
| 23-33 | 0000000020c | Period of sensor in counts. Counts occur at a rate of 460.8 kHz (14.7456MHz/32). |
| 35-46 | 0000000.000s | Period of sensor in seconds with millisecond resolution. Determined by dividing the above counts value by 460800. |
| 48-54 | -039.4C | Temperature measured at light sensor in degrees C. The value is averaged and presented every 4.3 seconds. Leading space for positive value. Leading negative sign (-) for negative value. |
| 55-63 | 00000413 | Serial number (8 digits). Each unit has its own unique serial number. |
| 64-65 | CL RF | Carriage return (0xd), Line feed (0xa). |

An example is:

8.8.1 Interval reporting period setting

Executing the command “P#####x” (note upper case “P”) sets the period of the timed interval reports to the EEPROM and RAM for booting and immediate use.

Executing the command “p#####x” (note lower case “p”) sets the period of the timed interval reports to RAM only for immediate use.

The units are seconds. For example, the command “p0000000360x” sets the reporting time to once every 360 seconds.

8.8.2 Threshold setting for interval reporting

Executing the command “T#####.##x” (note upper case “T”) sets the threshold of the timed interval reports to EEPROM and RAM for boot and immediate use.

Executing the command “t#####.##x” (note lower case “t”) sets the threshold of the timed interval reports to RAM for immediate use only.

The units are $\frac{\text{magnitudes}}{\text{arcsecond}^2}$. For example, t00000016.00x limits reporting to values only over 16.00 $\frac{\text{magnitudes}}{\text{arcsecond}^2}$.

8.8.3 Interval setting response

Either making the request “Ix” (note upper case “I”) or any request to set the interval report setting produces the following response shown in table 8.32:

Table 8.32: Response of viewing or setting interval reporting parameters

| Column | Example value | Description |
|--------|----------------------|---|
| 0 | I | Interval settings from EEPROM and RAM are being returned. |
| 2-12 | 0000000360s | Interval period that was set into EEPROM. |
| 14-24 | 0000300360s | Interval period that was set into RAM. |
| 26-37 | 000000017.60m | Threshold value that was set into EEPROM. |
| 39-50 | 000000017.60m | Threshold value that was set into RAM. |
| 51-52 | CR | Carriage return (0xd), Line feed (0xa). |

An example response is:

I,0000000360s,0000000360s,000000017.60m,000000017.60mCR
0123456789 123456789 123456789 123456789 123456789 12

8.9 Simulation commands

The following simulation commands help to determine the results of $\frac{mag}{arcsec^2}$ readings derived from the light and temperature sensors.

When using the Simulation mode of the SQM-LL, make sure that nothing else interrupts the sequence of readings such as external programs reading from the SQM-LL, or settings of Interval reporting inside the SQM-LL. To read the internal simulation values, issue the **sx** command, the response is shown in table 8.33:

Table 8.33: Response of request for internal simulation values

| Column | Example value | Description |
|--------|--------------------|--|
| 0 | s | Confirmation of the command. |
| 1 | , | Separation character. |
| 2-12 | 0000000360c | Number of counts. |
| 13 | , | Separation character. |
| 14-24 | 0000000360f | Frequency in Hz. |
| 25 | , | Separation character. |
| 26-37 | 0000000244t | Temperature ADC value as seen by the CPU. See Equation 8.1 . |
| 38-39 | cr lf | Carriage return (0xd), Line feed (0xa). |

An example response is:

s,0000000360c,0000000360f,0000000360t_{RF}cr lf
0123456789 123456789 123456789 12345678

To convert raw temperature value to degrees C:

$$DegC = \frac{\frac{raw \times 3.3}{1024} - 0.5}{0.01} \quad (8.1)$$

To convert degrees C value to raw temperature:

$$raw = \frac{(DegC \times 0.01 + 0.5) \times 1024}{3.3} \quad (8.2)$$

To set the internal simulation values and read the calculated response, issue the **S...x** command as detailed in Table 8.34. The result of that command is shown in Table 8.35.

Table 8.34: Request simulation (S....x)

| Column | Example value | Description |
|--------|-------------------|--|
| 0-1 | S, | Initiation of Sx command. |
| 2-11 | 0000000360 | Simulated counts. |
| 12 | , | Separation character (can be anything except x). |
| 13-22 | 0000000360 | Simulated Frequency in Hz |
| 23 | , | Separation character (can be anything except x). |

Table continued on next page ...

Table 8.34 – *continued from previous page*

| Column | Example value | Description |
|--------|---------------|---|
| 24-33 | 00244 | Simulated Temperature ADC value. See Equation 8.1 . |
| 34 | x | Terminating character. |
| 35-36 | CRF | Carriage return (0x0d), Line feed (0x0a). |

An example command is:

S,0000000360,0000000360,0000000360xCRL
0123456789 123456789 123456789 123456

Table 8.35: Response of setting simulation values (S...x)

| Column | Example value | Description |
|--------|----------------------|---|
| 0-1 | S, | Confirmation of S...x command. |
| 2-13 | 0000094000c, | Simulated counts. |
| 14-25 | 0000000000f, | Simulated frequency in Hz. |
| 26-37 | 0000000245t, | Simulated temperature ADC value. See Equation 8.1 . |
| 38-39 | r, | Beginning of calculated readings. |
| 40-47 | -18.04m, | Calculated $\frac{mag}{arcsec^2}$. |
| 48-60 | 0000000000Hz, | Frequency used for calculation. |
| 61-72 | 0000094000c, | Counts used for calculation. |
| 73-85 | 0000000.204s, | Calculated period from counts. |
| 86-92 | -029.0C | Temperature used for calculation. |
| 93-94 | CRF | Carriage return (0x0d), Line feed (0x0a). |

An example response is:

S,0000094000c,0000000000f,0000000245t,r, 18.04m,0000000000Hz,0000094000c,0000000.204s, 029.0CRLF
0123456789 123456789 123456789 123456789 123456789 123456789 123456789 123456789 123456789 1234

9 Installation

9.1 Mechanical installation

Unihedron sells an enclosure that is suitable for mounting either the SQM-LE, SQM-LU, SQM-LR, SQM-LU-DL into. You can read more about it, including plans to build your own at www.unihedron.com/projects/sqmhousing/ .



Figure 9.1: Housing

9.1.1 Cover selection

If the unit is to be mounted in exposed location, we recommend the Unihedron plastic weatherproof housing with glass window plate, or an acrylic dome. Acrylic domes will last 2-3 years but eventually weather on the surface. It is not clear that this will affect the reading much. The best test would be to swap a weathered and new one back and forth when changing one out. Presumably the main consideration would be to keep the domes clean every so often and to make sure that the mounting plane is painted black to that it doesn't reflect light back to the inside of the dome and then back into the meter.

Source of scrylic domes: www.globalplastics.ca/domes.htm

9.1.2 Cover calibration

Since the meter is not weather-proof, it must be protected in some way from the elements. The Unihedron meter housing or a plastic dome is recommended. This will reduce the incoming light (approximately 15-20%).

Because a covering will reduce the incoming light, the resultant reading will be darker (higher $\frac{mag}{arcsec^2}$ value). The offset determined by a simple light experiment should be subtracted from the reading.

The light calibration offset is like a starting point for readings, and since the cover glass makes readings darker, the offset should compensate by starting a brighter value.

Apply the cover subtraction offset as a negative value, i.e. if you measured 16.60 outside the covering, then 16.75 under the dome, then an offset of -0.15 should be applied to all readings.

An example using the UDM software; if your offset is -0.15 and your factory calibrated light calibration offset is 19.92 then you should change the light-calibration-offset on the calibration-tab to 19.77. European users will see and use a comma instead of a decimal point (eg. 19,77).




Figure 9.2: Example cover calibration

9.1.3 Cover maintenance

Keep the covering clean of dust, water, ice, and bird droppings.

10 Default settings

Ideal crossover firmware. Set in UDM:ReportInterval tab. Allows `BooTLoad ENable` feature for faster startup and filling the temperature and period averaging cells for quicker readings after powerup. See table 8.29 for details on setting and getting the ideal crossover setting.

11 Firmware upgrade

See the UDM “Firmware tab” section on page 57 for instructions on updating the firmware in the SQM-LL.

11.1 Details

The SQM-LL contains a micro-controller that is equipped with a boot-loader mechanism which is enabled for a few seconds after reboot/reset.

Intel hex strings sent to the unit are used to overwrite program memory. The following link contains a thorough description of the Intel Hex format: <http://en.wikipedia.org/wiki/.hex>

The basic requirements for firmware uploading are:

1. Reset micro-controller by sending the hex character 0x19
2. Within a few seconds, send the first Intel hex record. The colon “:” character indicates the beginning of an Intel Hex record.
3. Wait for a response of “**Ok**” followed by “**CR LF**” which indicates that the record was processed properly.
4. Continue sending records and waiting for the acknowledgement.
5. The unit will reset on its own when no more records have been sent for a few seconds.

12 Calibration

The SQM-LL is factory calibrated and a sheet of the calibration values was provided with the unit. Contact Unihedron with your unit's if you need a copy of the original calibration sheet.

Some possible reasons for recalibration are:

1. A new covering/housing is being used besides the small case that the unit was shipped with.
2. A regular maintenance program is desired. There is no great need for this as the SQM-LL has no analog components.
3. Compensation for aged housing, if a plastic dome is used that might have degraded over time.
4. Replaced lens or changed field of view for experimental reasons.

12.1 Recalibration

There is no easy way to perform in-field recalibration. It is recommended to send the unit back to Unihedron for proper calibration. There is a nominal fee for recalibration and shipping. Please contact Unihedron for details.

12.2 Light calibration

The sensor must have a reference point for an amount of light against the signal produced. It is not recommended that this be done after factory calibration and relied upon since an improper setup will result in non-standard results.

A fluorescent light or green LED is used to simulate the spectrum that the meter would see during the night sky. A light meter is used to adjust the light reading to 13.5 fc at the place of the SQM-LL. The light calibration routine inside the SQM-LL expects to see this value.

The light that the SQM-LL and light meter see must be coming from an evenly lit surface.

The “light calibration” command can be sent to the unlocked SQM-LL to set the calibration value.

12.3 Dark calibration

The optical sensor in the SQM-LL produces a reading even when totally dark. This “dark level” reading must be determined so that the meter can compensate for it.

The method of dark calibration is simply to prevent any light from entering the meter then execute a “dark calibration” command to the unit. A darkroom bag is one way to prevent light from entering the unit.

The optical sensor provides timed pulses depending on the amount of light entering. In a dark environment the pulses will be long. The meter has a timeout of 300 seconds, so the dark calibration will take at least 5 minutes (300 seconds) to perform.

Place the unit in a dark environment and monitor the timed readings (rx reading request) until they are consistent, normally the value is in the 80-300 second range, then execute the “dark calibration” command.

12.4 Confirmation

Once the calibration has been done, you should be able to get a light reading from the unit at the calibration light level of the same value as the value printed on your calibration sheet in the “Calibration offset” field. Normally this field has a value of 8.71 mags/arcsec².

13 Troubleshooting

Table 13.1: Reading seem too bright

| | |
|----------|---|
| Problem | The meter reads values that are brighter than expected. |
| Cause | A light may be shining into the field of view of the meter. Or, the IR filter may have fallen out of the lens. |
| Solution | Ensure that there are no extra sources of visible light in the field of view of the meter. Also, some infrared security cameras emit enough light in the spectrum that the meter will pick up. Inspect lens for IR filter. You should see a light blue colour inside the lens. |

Table 13.2: Reading is 0.00mpsas

| | |
|----------|--|
| Problem | The meter reads values of 0mpsas. |
| Cause | In bright light over about 6mpsas (even indoors) the meter saturates and will produce a reading of 0mpsas. |
| Solution | Test the meter in a darker setting or place a cover over the meter while doing indoor testing. Note: in complete darkness (like a photo-darkroom), the meter may timeout and also produce strange readings. |

Table 13.3: Cannot Find UDM software

| | |
|----------|---|
| Problem | Microsoft Edge cannot find UDM software on the CD. Error “Can’t reach this page”. |
| Cause | Microsoft Edge has protections in place to hide file lists on remote drives. |
| Solution | Use the File Manager to navigate the CD to the Windows directory then install from there. Or, get the latest Windows version of UDM from the Unihedron website: unihedron.com/projects/darksky/cd/Windows/ |

Table 13.4: Darkroom-bag readings incorrect

| | |
|----------|---|
| Problem | Meter readings from inside a darkroom-bag are not dark enough or do not change. |
| Cause | In completely dark environments, the meter cannot collect enough light to even resolve one reading. |
| Solution | Test the meter in natural darkness outside at night. |

Table 13.5: UDM shuts down after starting

| | |
|----------|---|
| Problem | UDM shuts down after starting |
| Cause | An improper startup option may be stored. |
| Solution | Remove the [Startup options] section from the config file using a text editor. Mac and Linux stores the configuration in udm.cfg, Windows stores the configuration in udm.ini . See 7.3 |

14 Glossary

Table 14.1: Glossary of terms

| | |
|----------|--|
| ADC | Analog to Digital Converter. A device used to convert an analog signal into a digital value. |
| CCD | Charge coupled device is a type of image sensor. |
| EEPROM | Electrically Erasable Programmable Read Only Memory is a type of memory that retains its contents after the power has been removed. This type of memory has a limited write/erase cycle as well as a lifetime for data retention. In the SQM-LL, the parameters in the micro-controller can be written 1 million times and last for 100 years. |
| Firmware | The program that resides inside the device. In the case of the Unihedron SQM products, it is the software that runs the device including reading and reporting the light values. |
| FITS | Flexible Image Transport System is an open standard defining a digital file format useful for storage, transmission and processing of scientific and other images. |
| GPS | Global Positioning System. A GPS receiver may be connected to a computer to allow UDM to integrate the location information into the logged data. See UDM for mode details. |
| mpsas | Magnitudes per square arcsecond. The unit of measurement reported by the SQM. |
| NMEA | National Marine Electronics Association data format that the GPS receiver produces. |
| RAM | Random Access Memory. Temporary memory that only retains data while power is applied. |
| UDM | Unihedron Device Manager is software used to access the SQM series of meters. |

15 Bibliography

- [1] Christopher Kyba, etc., *Worldwide variations in artificial skyglow*. PNAS, Volume 1, Issue 6, 2014. <https://www.nature.com/articles/srep08409>
- [2] Wikipedia, *Apparent Magnitudes of Known Celestial Objects*. http://en.wikipedia.org/wiki/Apparent_magnitude
- [3] Schaefer, B.E. Feb. 1990. Telescopic Limiting Magnitude. PASP 102:212-229 http://adsbit.harvard.edu/cgi-bin/nph-iarticle_query?bibcode=1990PASP..102..212S
- [4] Olof Carlin, Nils. About Bradley E. Schaefer, Telescopic limiting Magnitudes, Web page discussion of brightness in Schaefer (1990) and Clark (1994). <http://w1.411.telia.com/~u41105032/visual/Schaefer.htm> (accessed 7/2003)
- [5] NELM Converter, K. Fisher fisherka@csolutions.net Rev. 8/2006 <http://unihedron.com/projects/doug/darksky/NELM2BCalc.html>
- [6] Moon Phase Pascal code in UDM is from the public domain library: Moon.pas Copyright 1997-2001 Andreas Hörstemeier Version 2.0 2001-07-07 Algorithms taken from the book "Astronomical Algorithms" by Jean Meeus

Company information

| | |
|-----------------|--|
| Mailing address | Unihedron 4 Lawrence Avenue Grimsby, Ontario L3M 2L9 Canada |
| Telephone | (905) 945-1197 |
| Website | unihedron.com |